

DRAFT PROJECT IMPACT REPORT

BOSTON MEDICAL CENTER ENERGY FACILITY

MARCH 22, 2010



SUBMITTED TO:
BOSTON REDEVELOPMENT AUTHORITY
ONE CITY HALL SQUARE
BOSTON, MA 02201

SUBMITTED PURSUANT TO ARTICLE 80 OF THE BOSTON ZONING CODE

SUBMITTED BY:
BOSTON MEDICAL CENTER CORPORATION
ONE BOSTON MEDICAL CENTER PLACE
BOSTON, MA 02118

PREPARED BY:
RFWalsh collaborative partners
51 SLEEPER STREET
BOSTON, MA 02210

IN ASSOCIATION WITH:
TSOI/KOBUS & ASSOCIATES
VANDERWEIL ENGINEERS
OAK ENGINEERS
HOWARD/STEIN-HUDSON
RUBIN AND RUDMAN LLP
EPSILON ASSOCIATES, INC.
HALEY AND ALDRICH



TABLE OF CONTENTS

1.0	Summary and Project Description	1-1
1.1	Project Identification	1-1
1.2	Introduction	1-2
	1.2.1 Boston University Medical Center	1-2
	1.2.2 Project Summary	1-3
1.3	Boston University Medical Center Sustainable Initiatives and Infrastructure	1-4
	1.3.1 The Green Committee	1-4
	1.3.2 Sustainable Infrastructure	1-5
1.4	Project Description	1-9
	1.4.1 Summary of Project Need	1-9
	1.4.2 Project Site	1-9
	1.4.3 Building Program	1-10
	1.4.4 Approximate Project Dimensions	1-10
	1.4.5 Project Schedule	1-10
1.5	Project Objectives	1-22
1.6	Project Benefits	1-22
	1.6.1 Direct Project Benefits	1-22
	1.6.2 Annual Property Taxes / PILOT	1-23
	1.6.3 Linkage	1-23
	1.6.4 Other Economic Benefits	1-23
1.7	Anticipated Permits, Reviews, and Approvals	1-24
1.8	Zoning	1-24
1.9	Public Approval Process	1-25
2.0	Assessment of Development Review Components	2-1
2.1	Urban Design	2-1
	2.1.1 Introduction	2-1
	2.1.2 Urban Design Principles	2-1
	2.1.3 Existing Context and Project Location	2-1
	2.1.4 Height and Massing	2-2
	2.1.5 Material and Image	2-2
	2.1.6 Vehicular Access and Circulation	2-3
	2.1.7 Site Improvements	2-3
2.2	Sustainable Design	2-10
	2.2.1 Introduction	2-10
	2.2.2 Energy System Summary	2-10
	2.2.3 Design	2-11
2.3	Transportation	2-12
	2.3.1 Vehicle Traffic	2-12
	2.3.2 Service and Loading	2-12
	2.3.3 Bicycle Facilities	2-12
	2.3.4 Construction Period Impacts	2-13
2.4	Environmental Protection	2-15
	2.4.1 Wind	2-15
	2.4.2 Daylight	2-15
	2.4.3 Shadow	2-15
	2.4.4 Solar Glare	2-15
	2.4.5 Air Quality	2-16
	2.4.5.1 Emissions Summary	2-16

TABLE OF CONTENTS

2.4.5.2	Background Air Quality	2-17
2.4.5.3	Air Quality Modeling	2-20
2.4.5.4	AERMOD Results	2-21
2.4.6	Noise	2-23
2.4.6.1	Introduction	2-23
2.4.6.2	Noise Terminology	2-23
2.4.6.3	Noise Regulations and Criteria	2-25
2.4.6.4	Existing Conditions	2-26
2.4.6.5	Future Sound Level of Project	2-34
2.4.6.6	Conclusions	2-36
2.4.7	Flood Hazard Zones/Wetlands	2-38
2.4.8	Geotechnical/Groundwater	2-38
2.4.8.1	Subsurface Conditions	2-38
2.4.8.2	Foundation Methodology	2-38
2.4.8.3	Excavation Support	2-38
2.4.8.4	Groundwater Conditions	2-38
2.4.9	Water Quality	2-39
2.4.10	Solid and Hazardous Wastes	2-40
2.4.10.1	Existing Soil Conditions	2-40
2.4.10.2	Construction Waste Disposal	2-40
2.4.10.3	Solid Waste Generation and Recycling	2-40
2.4.11	Rodent Control	2-40
2.4.12	Wildlife Habitat	2-40
2.5	Construction Management Plan	2-41
2.5.1	Construction Schedule and Coordination	2-41
2.5.2	Construction Staging and Public Safety	2-42
2.5.3	Construction Employment and Worker Transportation	2-42
2.5.4	Construction Truck Routes and Deliveries	2-42
2.5.5	Construction Noise	2-43
2.5.6	Construction Air Quality	2-43
2.5.7	Construction Waste	2-44
2.5.8	Protection of Utilities	2-44
2.6	Historic and Archaeological Resources	2-44
2.6.1	Historic Resources	2-44
2.6.2	Archaeological Resources	2-45
2.7	Infrastructure Systems	2-45
2.7.1	Introduction	2-45
2.7.2	Regulatory Framework	2-46
2.7.3	Wastewater	2-46
2.7.3.1	Existing Wastewater	2-46
2.7.3.2	Demand/Use	2-46
2.7.3.3	Proposed Connection	2-46
2.7.4	Domestic Water and Fire Protection	2-47
2.7.4.1	Existing Water Supply System	2-47
2.7.4.2	Proposed Connection	2-47
2.7.5	Stormwater Management	2-48
2.7.5.1	Existing Conditions	2-48
2.7.5.2	Proposed Conditions	2-48
2.7.6	Anticipated Energy Needs	2-48
2.7.6.1	Natural Gas Service	2-48
2.7.6.2	Electrical Service	2-49

TABLE OF CONTENTS

2.7.6.3	Steam	2-49
2.7.6.4	Telecommunications	2-49
3.0	Coordination with Other Governmental Agencies	3-1
3.1	Introduction	3-1
3.1.1	Architectural Access Board Requirements	3-1
3.1.2	Massachusetts Environmental Policy Act	3-1
3.1.3	Massachusetts Historical Commission / South End Landmark District Commission	3-1
3.1.4	Boston Civic Design Commission	3-1
3.1.5	Other Permits and Approvals	3-1

4.0 Response to Comments 4-1

Appendices

Appendix A	Context Site Photos
Appendix B	Shadow Studies
Appendix C	LEED New Construction 2009 Checklist
Appendix D	Green Committee September 2009 programs report
Appendix E	BRA Scoping Determination and Comment Letters

List of Figures

Section 1

Figure 1-1	Project Location – USGS Locus Map	1-6
Figure 1-2	Project Location – Aerial Locus Map	1-7
Figure 1-3	Project Location – Campus Locus Map	1-8
Figure 1-4	Site Plan	1-11
Figure 1-5	Basement Floor Plan	1-12
Figure 1-6	Level 1 Floor Plan	1-13
Figure 1-7	Level 2 Floor Plan	1-14
Figure 1-8	Level 3 Floor Plan	1-15
Figure 1-9	Penthouse Floor Plan	1-16
Figure 1-10	Roof Plan	1-17
Figure 1-11	North Elevation	1-18
Figure 1-12	East Elevation	1-19
Figure 1-13	South Elevation	1-20
Figure 1-14	Section A – Looking North	1-21

Section 2

Figure 2-1	Aerial View Looking East	2-4
Figure 2-2	Perspective Looking West	2-5
Figure 2-3	Perspective Looking North	2-6
Figure 2-4	View from Albany Street	2-7
Figure 2-5	View from Massachusetts Avenue Connector	2-8
Figure 2-6	Night View from Massachusetts Avenue Connector	2-9
Figure 2-7	BUMC Campus Bicycle Facilities	2-14

TABLE OF CONTENTS

Figure 2-8	DEP Monitoring Station	2-19
Figure 2-9	Noise Monitoring Locations	2-28
Figure 2-10	Baseline Long-Term Noise Monitoring	2-33
Figure 2-11	Schematic Site Plan	2-50

List of Tables

Section 1

Table 1-1	Proposed Project Square Footage Table	1-10
Table 1-2	Anticipated Permits, Reviews, and Approvals	1-24
Table 1-3	Community, Public, City Agency Meetings	1-25

Section 2

Table 2-1	Short Term Turbine and Duct Burner Emissions	2-17
Table 2-2	Estimated Annual Emissions	2-17
Table 2-3	Observed Ambient Air Quality Concentrations	2-18
Table 2-4	Comparison of Project AERMOD Results with NAAQS	2-22
Table 2-5	City of Boston Zoning District Noise Standards	2-25
Table 2-6	Baseline Ambient Noise Measurements	2-30
Table 2-7	Continuous Ambient Noise Measurement	2-31
Table 2-8	Sound Power or Sound Pressure Level Data	2-36
Table 2-9	MassDEP Criteria Future Predicted Nighttime Sound Levels	2-37
Table 2-10	City of Boston Criteria Future Predicted Nighttime Sound Levels	2-37
Table 2-11	Hydrant Test Data	2-47

Section 4

Table 4-1	Comments Letters on the PNF	4-1
-----------	-----------------------------	-----

Section 1.0

1.0 SUMMARY & PROJECT DESCRIPTION

1.1 Project Identification

Project Name: Energy Facility

Address/Location: The proposed Energy Facility location is adjacent to the existing Power Plant building at 750 Albany Street at Boston University Medical Center.

Proponent: Boston Medical Center Corporation
One Boston Medical Center Place
Boston, MA 02118
(617) 638-6909

Ronald E. Bartlett, Vice President for Finance and Chief Financial Officer

Project Manager: RFWalsh collaborative partners
51 Sleeper Street, 8th Floor
Boston, MA 02210
(617) 778-0900

Jack C. Hobbs, FAIA, President and CEO
Donna M. Camiolo, Project Executive

Architect: Tsoi/Kobus & Associates, Inc.
One Brattle Square
P.O. Box 9114
Cambridge, MA 02138
(617) 475-4000

Greg Luongo, AIA, Principal

MEP Engineer: Vanderweil Engineers, LLP
274 Summer Street
Boston, MA 02210
(617) 423-7423

Garen H. Demirchian, P.E.

Civil Engineer: Oak Engineers
40 Merrimac Street, #R
Newburyport, MA 01950
(978) 465-9877

Sean Malone, P.E.

Geotechnical Consultant: Haley and Aldrich, Inc.
465 Medford Street, Suite 2200
Boston, MA 02129
(617) 886-7400

Mark Balfe, P.E.

1.0 SUMMARY & PROJECT DESCRIPTION

Transportation
Consultant: Howard/Stein-Hudson, Inc.
38 Chauncy Street, 9th Floor
Boston, MA 02111
(617) 482-7080

Jane Howard, Principal

Legal Counsel: Rubin and Rudman LLP
50 Rowes Wharf
Boston, MA 02110
(617) 330-7000

James H. Greene, Attorney

Air Quality and
Noise Consultant: Epsilon Associates, Inc.
3 Clock Tower Place, #250
Maynard, MA 01754
(978) 897-7100

Victoria Fletcher, Principal

1.2 Introduction

1.2.1 Boston University Medical Center

Boston Medical Center (“BMC”) is a part of the Boston University Medical Center along with Boston University Medical Campus (“BU Medical Campus”). Boston Medical Center Corporation (the “Proponent”) is pleased to submit this Draft Project Impact Report (“DPIR”) in response to the Boston Redevelopment Authority (“BRA”) Scoping Determination dated 11/16/09 in accordance with Article 80 Large Project Review process for the proposed Energy Facility (“Project”). This is pursuant to Section 80B of the Boston Zoning Code (“Code”). The Proponent respectfully requests that the BRA, in the Preliminary Adequacy Determination for such DPIR, waive further review, if, after reviewing the DPIR and the public comments, the BRA finds that such DPIR adequately describes the proposed Project’s impacts. This is pursuant to Section 80B-5.4(c)(iv) of the Code.

On May 18, 2000, the BRA approved the existing Boston University Medical Center IMP. Since that time, IMP amendments, Notices of Project Change (“NPC”) and proposals for small additions have been filed to obtain approval for new construction or rehabilitation projects, or to revise and update uses as previously reported. The most significant of these include: the rehabilitation of the 66,952 s.f. Surgical Building (May 2001 IMP Amendment); the replacement of the approved Medical Services Center with the 133,217 s.f. Moakley Building (July 2003 NPC); and the approximately 245,000 s.f. new Shapiro Ambulatory Care Center (August 2007 IMP Amendment). Most recently, the BRA approved the IMP Renewal (June 2009) extending the term for 2 years including an Amendment for a minor 845 s.f. expansion to the Emergency Department. Additionally, the BRA approved the IMP

1.0 SUMMARY & PROJECT DESCRIPTION

Amendment (January 2010) for the addition of the Albany Fellows Site and Graduate Student Housing Project.

BMC was incorporated as a Massachusetts charitable corporation July 1, 1996 with the merger of Boston City Hospital, Boston Specialty & Rehabilitation Hospital, and the Boston University Medical Center Hospital, referred to as University Hospital. BMC is a private, not-for-profit, 626-licensed bed, academic medical center located in Boston's historic South End. The hospital is the primary teaching affiliate for Boston University School of Medicine. Emphasizing community-based care, BMC, with its mission to provide consistently accessible health services to all, is the largest safety net hospital in New England. BMC provides a full spectrum of pediatric and adult care services, from primary to family medicine to advanced specialty care.

With the largest 24-hour Level 1 trauma center in New England, the Emergency Department had more than 129,169 visits in 2008. With 29,411 admissions and 953,510 patient visits in 2008, BMC provides a comprehensive range of inpatient, clinical and diagnostic services in more than 70 areas of medical specialties and subspecialties. In Fiscal Year 2008, the BMC operating budget was \$1 billion.

The mission of BMC is "to provide consistently excellent and accessible health services to all in need of care regardless of status and ability to pay." The objective of BMC is to meet the health needs of the people of Boston and its surrounding communities by providing high quality, comprehensive care to all, particularly mindful of the needs of the vulnerable populations through an integrated delivery system, in an ethically and financially responsible manner. The goals of the integrated system of care are to promote health and well being, meet the medical and public health needs of all served, and educate future physicians and caregivers.

1.2.2 Project Summary

BMC is proposing to build a new combined heat and power energy facility based on three core energy delivery concepts: reliability, efficiency, and reduced environmental impact. The new 48,000 s.f. facility will use state-of-the-art technologies to produce electricity and steam. The Energy Facility will be located adjacent to the Power Plant building located at 750 Albany Street on the BUMC Campus. (The Power Plant supplies chilled water to the campus and is the steam and electric distribution center for Boston University Medical Center and is not a true power plant.)

The BUMC Campus relies on many utilities and energy infrastructure facilities that are approaching their operating limits. The Energy Facility is intended to meet the majority of the electrical demand and all of the high pressure steam demand required by Boston University Medical Center as well as BioSquare through cogeneration. (Cogeneration is the simultaneous production of electric power and steam.) See Figures 1-1 to 1-3 for Project location locus maps. See Section 1.5 – Project Description for more information.

1.0 SUMMARY & PROJECT DESCRIPTION

1.2 Boston University Medical Center Sustainable Initiatives and Infrastructure

1.3.1 The Green Committee

Over the past ten years, Boston University Medical Center has taken steps to decrease its energy demand and improve energy efficiency throughout its campus. BMC established the Green Committee to oversee the direction, development, and implementation of sustainable programs and policies. The Green Committee is comprised of representatives from various Boston Medical Center departments. BU Medical Campus departments are also on the Green Committee and collaborate with BMC on campus-wide or shared programs.

In order to strengthen its initiatives, the Green Committee tracks the environmental and financial results of improvement programs, continuously reviews and improves existing programs, and identifies new improvement projects. It oversees the environmental strategies to ensure continuous improvement through various trending methods and control activities. Through effective communication, the committee relates Green program status throughout the organization and works with management, staff, and the public to increase awareness and participation in campus environmental programs and initiatives. (See Appendix D for the Green Committee September 2009 programs report.)

Through the leadership of the Green Committee and the Design and Construction Department, the implementation of sustainable design and construction elements in all of Boston University Medical Center's capital projects have increased significantly. The Carl J. & Ruth Shapiro Ambulatory Care Center (SACC), currently under construction, is registered with Green Guide for Health Care (GGHC) and is targeting a LEED Silver equivalent. The GGHC is based on the Leadership in Energy and Environmental Design (LEED) point system, the original national model for sustainable building design. Ultimately the Green Committee is dedicated to the continual development of its sustainable campus. As per the committee's charter, the goal is to promote the health of patients, visitors, employees, local communities, and the global community while operating economically and efficiently.

By creating and managing more sustainable energy systems and reducing its greenhouse gas emissions, Boston University Medical Center will align itself with City of Boston goals for environmental programs and green technologies. The Executive Order of Mayor Thomas M. Menino entitled "An Order Relative to Climate Action in Boston" (April 13, 2007) outlines sustainable practices adopted by the city including reduction of greenhouse gasses and improvement of overall energy efficiency for buildings. According to Climate: Change (the City of Boston's Climate Action Plan - December 2007), "78% of Boston's greenhouse gas emissions are related to buildings" (e.g. heating, cooling, and electricity). Within the report, the City of Boston encourages "all sectors of the community to use energy more efficiently in their facilities and...create environments that are more energy-efficient." The proposed Energy Facility will meet this challenge and reduce greenhouse gas emissions through the process of cogeneration. Cogeneration is considered an Eco-friendly "green" technology

1.0 SUMMARY & PROJECT DESCRIPTION

recognized by the Massachusetts Green Communities Act and the Massachusetts Technology Collaborative as a cost effective, scalable method of producing electricity and utilizing waste heat to increase efficiency at the host site.

1.3.2 Sustainable Infrastructure

Focused on environmental goals, Boston University Medical Center evaluated its campus infrastructure during the last ten years. Upgrades, replacements, and systems maintenance were performed in a manner that addressed obsolescence and allowed for efficiencies during future initiatives. Boston University Medical Center achieved demand-side energy savings through standardizing the use of energy-efficient lighting fixtures and water-saving plumbing fixtures and installing building automation systems controls to reduce the consumption of energy during off peak periods. Further, Boston University Medical Center implemented new procedures to manage infrastructure systems more efficiently overall.

Boston University Medical Center also centralized mechanical systems, such as chiller plants, and installed equipment that could be fueled by different sources. These measures help control cost and demand and create redundancy. Boston University Medical Center installed pipe and electrical infrastructure to allow for the connection of utilities from separately served ends of the campus. This new infrastructure improves the ability to maintain systems, provides opportunities for redundant energy delivery systems, and creates efficiencies. Having implemented the recommended energy efficiency and infrastructure improvements, Boston University Medical Center now needs to create an independent, efficient, environmental, and redundant energy source with the proposed Energy Facility. The Energy Facility will improve energy reliability and reduce the BUMC Campus carbon footprint. It will also eliminate the possibility of service failure or disruption that would be detrimental to the delivery of patient care in a 24/7 environment.

1.0 SUMMARY & PROJECT DESCRIPTION

Figure 1-1 Project Location – USGS Locus Map




Boston University Medical Center Boston, Massachusetts



Figure 1
USGS Locus Map

1.0 SUMMARY & PROJECT DESCRIPTION

Figure 1-2 Project Location – Aerial Locus Map



Boston University Medical Center Boston, Massachusetts



Figure 2
Aerial Locus Map

1.0 SUMMARY & PROJECT DESCRIPTION

1.4 Project Description

1.4.1 Summary of Project Need

The BUMC Campus relies on many utilities and energy infrastructure facilities that are approaching their operating limits. Boston University Medical Center infrastructure systems are largely dependent on purchased utilities with significant utilization of electrical power and steam. Currently Boston University Medical Center uses a steam distribution system that is at capacity and an electrical distribution system that is not designed to support future growth. The campus relies to a lesser degree on natural gas and oil. Those fuel sources are primarily for back-up systems within patient care and research buildings and spaces.

Boston University Medical Center currently utilizes electrical power through two power distribution centers on the BUMC Campus. These stations (at the Power Plant and the Evans Building) are both over 30 years old and are using out of date technology that is not supported by replacement parts without customization or reliance on refurbished equipment. One of these stations is operating within five percent of its rated capacity. The other is presently operating at 65 percent of its capacity, but services an area of significant anticipated growth. Given the age of these stations and projected energy demand, upgrades and modernization of electrical infrastructure will be required in the very near future.

Given increased reliance on technology and ever increasing minimum standards, Boston University Medical Center's requirements for powering and cooling patient care and research space create new demands that continue to outpace the ability to reduce the amount of utilities used in total.

Boston University Medical Center now faces the challenge of managing the availability and reliability of energy service which is critical to a major medical center. In order to support the campus growth, keep up with advancements in health care technology, and deliver clinical services 24/7, Boston University Medical Center requires a new energy facility to address these issues. The goals of the proposed Energy Facility Project are to reduce demand on existing taxed infrastructure, create energy and system redundancy, increase system efficiency, and reduce overall environmental impact.

1.4.2 Project Site

The proposed Energy Facility site is located adjacent to the existing Power Plant at 750 Albany Street on the BUMC Campus, just north of the Massachusetts Avenue Connector and west of East Concord Street. It is paved and used for parking. The proposed site area will be approximately 11,000 s.f. The general area is urban in nature. The adjacency to the existing Power Plant is necessary in order to tie in to the existing system and enhance operational efficiency. See Figures 1-1 through 1-3 for Project location locus maps.

1.0 SUMMARY & PROJECT DESCRIPTION

1.4.3 Building Program

The proposed Energy Facility is comprised of spaces designated for primary mechanical equipment such as combustion turbine generators (CTGs) and heat recovery steam generators (HRSGs), auxiliary systems and ancillary equipment, and the associated distribution infrastructure. Auxiliary systems include condensate and feed water systems, control system, natural gas, chemical treatment, ammonia, fuel gas piping, gas compressors, plant air systems, HVAC systems, and chilled water. Minor renovations will be made to the Power Plant to allow circulation between the two buildings. Other programmed spaces include a control room with a staff toilet and an electrical switchgear room. Refer to Table 1-1 for a more detailed breakdown. Each CTG will have a heat recovery steam generator to comprise one complete power island. Each power island will be provided with auxiliary systems and ancillary equipment necessary for production of steam and electricity through cogeneration.

The Energy Facility will be approximately 48,000 s.f. and approximately 100 feet in height from grade. Emissions stacks will be approximately 160 feet in height from grade. See Figures 1-4 through 1-14 for plans, sections, and elevations of the proposed Project. See Appendix A for context site photos.

At street level, the primary entrance to the building will be from a service road "interior" to the BUMC Campus on the south side of the site. The proposed building is bordered to the east and west by existing buildings. The north side of the site is planned to be developed as open space upon completion of the future Administration/Clinical Building for BMC.

1.4.4 Approximate Project Dimensions

Table 1-1 Proposed Project Square Footage Table

Energy Facility	Square Feet	Program and Comments
Level 0 (basement)	10,000	Electrical Switches, Water Softeners, Pumps and Storage Tanks
Level 1	12,000	Combustion Turbine-Generators and Heat Recovery System Generators (Gas Turbines and Boilers)
Mezzanine	1,000	Control Room, Emissions Control and Mechanical Equipment
Level 2	11,000	Switchgear Room, Boiler Economizers, Combustion Air Inlet Filters and Air Plenum
Level 3	11,000	Deaerators, Emergency Generator, CEMA, Electrical and HVAC Equipment
Penthouse	3,000	Gas Compressors, Cooling Tower and Rooftop Mechanical
Total Energy Facility Square Footage	48,000	

1.4.5 Project Schedule

Project construction is expected to commence in the 4th Quarter of 2010. Project construction is expected to conclude in the 2nd Quarter of 2012.


1.0 SUMMARY & PROJECT DESCRIPTION

Figure 1-4 Site Plan



1.0 SUMMARY & PROJECT DESCRIPTION


Figure 1-5 Basement Floor Plan



1.0 SUMMARY & PROJECT DESCRIPTION

Figure 1-6 Level 1 Floor Plan

LEVEL 1 FLOOR PLAN



PUBLIC35015421_nrc_12over_71611601a3 Comin 11/16/16 09:10:00 PM 11/16/16
TK&A | **TSOI / ROBUS & ASSOCIATES**
 ARCHITECTS © 2016 Tsoi Robus & Associates, Inc.


Boston Medical Center
Energy Facility

 **TRIGEN**
 A Veolia Energy Company


 BOSTON MEDICAL CENTER
 700 STATE STREET, BOSTON, MA 02116

1.0 SUMMARY & PROJECT DESCRIPTION

Figure 1-7 Level 2 Floor Plan



P:\BMC\2019\4-CD_Rev_1\Level_2_Floor_Plan_TK&A_Coord_11\BOSTONMEDIACENTER\REV_0225_PNF_FINAL_0225_PNF_FINAL.rvt

**Boston Medical Center
Energy Facility**


TRIGEN
A Veolia Energy Company

**BOSTON
MEDICAL**
CENTRAL
DISCIPLINARY CODE: 00000000000000000000

TK&A ✓ **TSOI / ROBUS & ASSOCIATES**
ARCHITECTS © 2019 Tsoi/Robus & Associates, Inc.


1.0 SUMMARY & PROJECT DESCRIPTION

Figure 1-8 Level 3 Floor Plan



1.0 SUMMARY & PROJECT DESCRIPTION

Figure 1-9 Penthouse Floor Plan



PENTHOUSE FLOOR PLAN

P:\ARCH020\5400_1616_Penthouse\1616_Penthouse.dwg, DCS: PWF, 11/10/09, 02:25 PWF: PWF
TK&A ✓ TEOI / KORUS & ASSOCIATES ARCHITECTS © 2009 Teo Korus & Associates, Inc.


Boston Medical Center
Energy Facility

TRIGEN
A Veolia Energy Company

BOSTON MEDICAL CENTER
www.bmc.org

1.0 SUMMARY & PROJECT DESCRIPTION

Figure 1-10 Roof Plan



1.0 SUMMARY & PROJECT DESCRIPTION

Figure 1-11 North Elevation

NORTH ELEVATION










Figure

1.0 SUMMARY & PROJECT DESCRIPTION

1-12 East Elevation

EAST ELEVATION




Figure

1.0 SUMMARY & PROJECT DESCRIPTION

1-13 South Elevation

SOUTH ELEVATION



BOSTON MEDICAL CENTER
EXCEPTIONAL CARE. WITHOUT EXCEPTION.

TRIGEN
A Veolia Energy Company

Boston Medical Center
Energy Facility


TK&A ✓

TSOI / KOBUS & ASSOCIATES
ARCHITECTS

© 2017 Tsoi/Kobus & Associates, Inc.

1.0 SUMMARY & PROJECT DESCRIPTION

Figure 1-14 Section A – Looking North



1.0 SUMMARY & PROJECT DESCRIPTION

1.5 Project Objectives

The following are the primary objectives of this Project:

- Reliability - The Energy Facility will add redundancy to Boston University Medical Center's existing energy supply and ensure a reliable power system – an especially important concept in operating a hospital. Currently, electricity is provided to the BUMC Campus by NSTAR and Trigen-Boston supplies the steam. Boston University Medical Center will stay connected to these existing suppliers in the event that back-up energy is needed (e.g. during peak periods, scheduled equipment maintenance, or unexpected shutdowns).
- Efficiency - The Energy Facility will be located close to where Boston University Medical Center needs the power – a concept known as distributed generation. Placing a facility close to where the power is used is much more efficient and reliable than sending power farther away. This is based on the premise that with shorter distances for power to travel, there are fewer points for system failures. Further, the efficiency of the proposed system is approximately 72% as compared to a conventional single cycle power plant capable of operating at 33%.
- Reduced Environmental Impact - With the Energy Facility, Boston University Medical Center will be able to make electricity and steam from the same process – a process known as “combined heat and power” (CHP) or also referred to as “cogeneration”. In this process, a combustion gas turbine is fueled by natural gas to generate electricity. Waste heat from the combustion turbine is then sent to a Heat Recovery Steam Generator to produce usable steam. Boston University Medical Center uses steam to heat buildings and for medical equipment sterilization. Combining electric and thermal energy generation into a single integrated process reduces fuel consumption and the impact on the carbon footprint dramatically.

With the new facility, Boston University Medical Center plans to make 75% of its own electricity and 95% of its own steam. Within a year of operating this new facility, it is anticipated that net annual greenhouse gas emissions will be reduced in excess of 18,000 metric tons of carbon dioxide, equal to the absorption potential of approximately 4,000 acres of pine forest.

1.6 Project Benefits

1.6.1 Direct Project Benefits

- Job Creation and Retention - The Energy Facility will create construction jobs in addition to generating highly-skilled long-term operations and maintenance jobs. During the approximately eighteen month construction phase of the Project, thirty-nine construction

1.0 SUMMARY & PROJECT DESCRIPTION

- jobs will be created. Once the Project is complete, the Energy Facility will require seven new long-term operations and maintenance jobs.
- “Green” Job Creation and Training – The new full-time staff of the Energy Facility will receive training specific to the operation and maintenance of the associated state-of-the-art green technologies. Topics include: combustion turbines, heat recovery systems, emissions control equipment, dispatch optimization controls, and ISO New England programs.
 - Reduced Environmental Impact – Meeting this Project objective will help Boston University Medical Center to shrink its carbon footprint through lesser greenhouse gas emissions and lower its impact on the local environment. See Section 1.5 for more information.
 - Reduced Local Utility Impact – The proposed Energy Facility will enable Boston University Medical Center to generate 75% of its electricity and 95% of its steam. This subsequently decreases Boston University Medical Center’s impact on the locally taxed energy infrastructure.
 - Reduced Energy Costs – By producing steam and electricity through cogeneration, Boston University Medical Center will decrease its energy costs.

1.6.2 Annual Property Taxes / PILOT

Although much of the BUMC Campus property is tax-exempt, BMC contributes annually to the City of Boston's Payment in Lieu of Taxes (PILOT) program.

1.6.3 Linkage

Upon approval of the Boston University Medical Center IMP in 2000, Boston University Medical Center entered into a Development Impact Project (“DIP”) Agreement with the BRA for its institutional projects which exceeded the threshold requirements of Article 80B of the Code. With the adoption of the new IMP for a new 10 year term commencing in 2010, Boston University Medical Center and the BRA will enter into a new DIP Agreement which will govern all new projects which exceed the thresholds set forth in Article 80B of the Code. Due to the size of the proposed Energy Facility of approximately 48,000 square feet, such project will not be a Development Impact Project. Future institutional projects to be undertaken by Boston University Medical Center under the new IMP that are designed to exceed 100,000 square feet, including the Administration/Clinical Building and the New Inpatient Building, will be subject to linkage in accordance with Article 80B, Section 80B-7 of the Code.

1.6.4 Other Economic Benefits

BMC’s community goals are to continue to provide effective and accessible services to vulnerable populations in the Boston community and to continue to expand efforts that deepen relationships with the communities they serve. Estimated BMC direct expenses on

1.0 SUMMARY & PROJECT DESCRIPTION

community benefit programs in fiscal year 2008 totaled \$18,434,426. Total community benefits programs expenditures in fiscal year 2008 per the Attorney General's guidelines were \$30,204,021. In addition, this expenditure and budget summary does not include the costs associated with numerous other programs and projects of BMC that make valuable contributions to the community.

BMC contributes to the local economy through employment of Boston residents and the purchase of goods and services from Boston businesses. BMC spent \$111 million in fiscal year 2008 for goods and services provided by Boston suppliers.

1.7 Anticipated Permits, Reviews, and Approvals

Table 1-2 below catalogs the permits, reviews, and approvals anticipated throughout the process.

Table 1-2 Anticipated Permits, Reviews and Approvals

Agency Name	Permit / Review / Approval
Federal	
Federal Aviation Authority	Construction Permit for Temporary Airspace Obstruction
State	
Executive Office of Environmental Affairs, Massachusetts Environmental Policy Act	Request for Advisory Opinion, or Secretary's Certificate, if required
Massachusetts Historical Commission	State Register Review, if required
Department of Environmental Protection, Division of Air Quality Control	Non-Major Comprehensive Air Plan Approval Environmental Results Program Certification
Department of Environmental Protection, Division of Water Pollution Control	Groundwater Discharge Permit Clean Water Act - Pre-treatment Standards Sewer Extension/Connection Compliance Certification
Massachusetts Water Resources Authority	Sewer Use Discharge Permit Individual Discharge/Sewer Permit
Department of Public Safety State Fire Marshall	Storage Tank Permit Flammable Storage License
Local	
Boston Redevelopment Authority	Article 80 Project Review
Boston Landmarks/South End Landmark District Commission	Application for Certificate of Design Approval
Boston Civic Design Commission	Design Review
Boston Groundwater Trust	Groundwater Trust Certification
Boston Transportation Department	Construction Management Plan
Boston Air Pollution Control Commission	Air Quality Control Permit
Boston Water and Sewer Commission	Construction Dewatering Permit Sewer/Extension/Connection Permit Stormwater Management Plan Site Plan Approval
Boston Inspectional Services Department	Building and Occupancy Permits
Boston Public Improvement Department	Street and Sidewalk Occupancy Permits
Boston Public Works Department	Street Opening Permit
Boston Fire Department	Plan Review
Joint Committee on Licenses	Flammable Storage License

1.0 SUMMARY & PROJECT DESCRIPTION

1.8 Zoning

The proposed Project site is located within the Boston University Medical Center Institutional Master Plan area and shown on Map 1P of the South End Neighborhood District which was adopted by MAP Amendment No. 273 by the Boston Zoning Commission on June 28, 2000, subsequent to the approval by the BRA on May 18, 2000 of the BUMC IMP. In accordance with the provisions of the Boston Zoning Code and Article 64, the South End Neighborhood District Zoning, projects within the district are subject to the provisions of the approved Institutional Master Plan. The Boston University Medical Center IMP was approved by the BRA on May 18, 2000 and the Zoning Commission on June 28, 2000, and approved by the Mayor on July 13, 2000. In accordance with provisions of Section 80D-2, institutional projects are required to be consistent with the approved Institutional Master Plan. The Project will be consistent with zoning upon approval of the new Boston University Medical Center IMP by the BRA and the Zoning Commission which is filed contemporaneously with this DPIR.

1.9 Public Review Process

The Boston Redevelopment Authority (BRA) has established a Task Force representing the area community to participate in the public review of the Project as part of the Boston University Medical Campus IMP. The Proponent had several meetings with the Task Force as well as public and city regulatory agencies and will continue an open and inclusive public process. Table 1-3 below provides a list of meetings that have been held on the Project since the filing of the PNF in September 2009.

Table 1-3 Community, Public, City Agency Meetings

Date	Group	Location
9/22/09	Worcester Square Neighborhood Association	Newton Pavilion, Conf. Rooms C/D
9/28/09	Task Force – BUMC IMP Introduction	Newton Pavilion, Conf. Rooms C/D
10/8/09	South End Landmarks Staff Planner	City Hall, Rm. 805
10/8/09	BRA Design Staff	City Hall, 9 th Floor
10/13/09	Boston Water & Sewer Commission	980 Harrison Avenue
10/13/09	BRA Scoping Session	City Hall, 9 th Floor, BRA Board Room
10/13/09	Task Force – Energy Facility	Menino Pavilion, Conf. Room A
10/14/09	Public Improvements Commission	City Hall, 7 th Floor
10/19/09	Boston Transportation Department	City Hall, Rm. 721
10/20/09	BRA Public Meeting	BioSquare, 670 Albany Street
10/23/09	Office of Jobs & Community Services	43 Hawkins Street
11/9/09	Task Force – BUMC Campus Tour	Talbot Building
11/10/09	Boston Civic Design Commission (BCDC) – IMP	City Hall, Rm. Piemonte Room
12/22/09	BCDC Subcommittee – Energy Facility	City Hall, Rm. 937A
2/23/10	BCDC Subcommittee – Energy Facility	City Hall, Rm. 933A
3/4/10	South End Landmarks District Commission	City Hall, Rm. 801

Section 2.0

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

2.1 Urban Design

2.1.1 Introduction

From the outset of the merger of Boston City Hospital, Boston Specialty and Rehabilitation Hospital, and University Hospital in 1996, the dominant urban design objective of BMC has been to create a cohesive medical center campus. It has also been a goal to integrate the overall campus with the surrounding neighborhoods through sensitive building, open space planning and site beautification along the periphery of the campus. The combination of these design principles will continue to enhance the physical image of the BUMC Campus as well as improve patient, staff and student perceptions of Boston University Medical Center.

2.1.2 Urban Design Principles

The Energy Facility is designed in the context of future development proposed for the South of Albany Campus defined in the recently submitted Boston University Medical Center IMP. It is in this context that important urban planning principles become the guidelines for its design. These principles include:

- Transforming the Albany Street campus image;
- Complementing existing context, i.e. massing, scale and materials;
- Creating a clear and welcoming sense of arrival;
- Enhancing open space opportunities on the campus;
- Developing pedestrian-friendly street edges;
- Enhancing accessibility to parking and existing buildings;
- Integrating sustainable design principles and operations; and
- Planning for future long-term growth and transformation.

2.1.3 Existing Context and Project Location

The current Albany Street edge is defined by varying building setbacks and urban densities. The buildings have different vintages and styles. As BMC evaluated expansion and renovation opportunities, it began to recognize the Albany Street edge of the campus as a primary arrival zone. BMC thusly decided to transform the Albany Street image through urban planning and various street level improvements, such as plantings and landscaping. The Shapiro Ambulatory Care Center (SACC), which is currently under construction, marks the first phase in a long-term objective of transforming the nature and image of the Albany Street edge of the BUMC Campus.

The proposed location of the Energy Facility to the east of the existing Power Plant will begin to better define the Albany Street edge, allow for future development of the South of Albany Campus, and align with the previously mentioned urban planning principles. As future phases of the Master Plan are developed, the desired balance of density and open space enhancements, and further definition of Albany Street will be realized.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

The Energy Facility will abut the existing Power Plant to the west and will be shorter than that building in overall height. (See Section 2.1.4 and Figures 2-1 through 2-6.) The Project will closely border the Chief Medical Examiner's Office building to the east. The north side of the site will be developed as open space in conjunction with the construction of the future Administration/Clinical Building for BMC. This configuration of buildings will continue to capitalize on the unique open space characteristics of the medical campus and will provide relief for pedestrians and staff. It will also establish a direct relationship with the views from the public elevator lobby of the Shapiro Ambulatory Care Center on the opposite side of Albany Street. The south side of the site fronts the Massachusetts Avenue Connector, a major vehicular approach. See Appendix A for context site photos.

2.1.4 Height and Massing

The height and massing are primarily dictated by dimensional clearances required for the large pieces of equipment to be housed within the building envelope. The height of the building will be approximately 100 feet to the top of the partially enclosed penthouse level. The north face will extend approximately fifteen feet in front of the north face of the existing Power Plant. The existing staff parking along Albany Street will be maintained until the proposed Administration/Clinical Building and open space is developed. The south side is bound by setbacks associated with the Roxbury Canal.

Two 6'-0" diameter exhaust stacks will be approximately 160 feet above grade. They will be located adjacent to the taller portion of the existing Power Plant to reduce the perceived height. The height (to the top of the roof) of the Energy Facility will be approximately 30'-0" shorter than the height (to the top of the roof) of the Power Plant.

The Project's height and massing are consistent and compatible with the institutional scale and density of the existing BioSquare development to the east and Crosstown development to the west. The massing of the Energy Facility also establishes a relationship with the scale and massing of the Shapiro Ambulatory Care Center across Albany Street. Likewise, the change in plane of the Shapiro Ambulatory Care Center street wall along Albany Street relates to the footprint of the Energy Facility and the future open space that will be developed in front of the Project. This future open space will provide visual interest for patients and staff traveling within the elevator lobbies of the Shapiro Ambulatory Care Center. These relationships will contribute to the creation of a pedestrian sensitive environment along Albany Street.

See Figures 2-1 and 2-6 for aerial and perspective views.

2.1.5 Material and Image

Simple massing and a minimal material palette are proposed for the Project. Dark grey metal panels and curtain wall glazing will be featured establishing a relationship with the

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

existing Power Plant. The building's simple form celebrates its utilitarian function while softening the visual impact to the neighborhood to the north.

A large expanse of curtain wall is proposed along the north and south ends facing Albany Street and the Massachusetts Avenue Connector, respectively. These large visual portals will provide passers-by glimpses into this facility highlighting its "green" technology and operations. From the north, the large scale curtain wall is organized in a top and bottom segment separated by a louver which brings the scale down to the pedestrian level along Albany Street. From the south, the large scale curtain wall expression relates to the expression of the existing Power Plant along this edge. The south façade of the Energy Facility responds appropriately to the macro scale of the Massachusetts Avenue Connector and complements the other architectural statements along the Expressway and Massachusetts Avenue Connector. Bold color will be applied internally at the emergency egress stairwells that flank the side of the curtain wall at each end of the building. This use of color will add visual interest and animate these edges.

Small scale vertical openings, louvers and a pattern of horizontal reveals are proposed along the east façade. These elements help break down the scale of the massing along this face and further add visual interest to this prominent view when approached from the Massachusetts Avenue Connector.

At night, the facility will be internally illuminated during limited hours to enhance the prominence of this site. The Energy Facility will act as a visual gateway to the BUMC Campus and will represent Boston University Medical Center's and the City of Boston's forward-thinking approach to sustainable development and environmental responsibility.

2.1.6 Vehicular Access and Circulation

Normal staff access and small material deliveries for the Energy Facility will be via existing Power Plant entrances and loading docks located along the Albany Street side of the existing facility. A loading dock and service access is planned on the south side of the Energy Facility for routine maintenance and to accommodate deliveries of large equipment and regular deliveries of materials to support ongoing operations. The existing fence at the helipad will be slightly modified to allow truck access from Albany Street via the East Concord Street Extension to the rear of the Energy Facility.

2.1.7 Site Improvements


Sidewalk and landscaping improvements along the Project frontage at Albany Street will occur as part of the previously approved Shapiro Ambulatory Care Clinic (SACC). Improvements include new scored concrete sidewalks with a brick paving strip, new double-acorn street lighting and new street trees and tree grates. Additionally, pedestrian ramps will be reconstructed and include detectable warning pavers. The vehicle ramp to the staff parking lot of the existing Power Plant will also be reconstructed and include detectable

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

warning pavers. (See Figure 1-4, Site Plan for the rendered improvements associated with the SACC.) The existing staff parking lot will be re-paved and re-striped.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

Figure 2-1 Aerial View Looking East



Figure

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

2-2 Perspective Looking West

Perspective Looking West



P:\BOSTON_MEDICAL_CENTER_ENERGY_FACILITY\ARCHITECTURE\REVIEWS\2015\150515_PERSPECTIVE_LOOKING_WEST.rvt

Boston Medical Center
Energy Facility

BOSTON MEDICAL CENTER
PROFESSIONAL CARE, WITHOUT COMPROMISE



TRIGEN
A Veolia Energy Company

TK&A ✓

TSDI / ROBUS & ASSOCIATES
ARCHITECTS © 2015 TSDI/Robus & Associates, Inc.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

Figure 2-3 Perspective Looking North



2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

Figure 2-4 View from Albany Street



2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

Figure 2-5 View from Massachusetts Avenue Connector



2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

Figure 2-6 Night View from the Massachusetts Avenue Connector



2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

2.2 Sustainable Design

2.2.1 Introduction

The proposed Energy Facility represents Boston University Medical Center's commitment to environmental responsibility and aligns itself with the City of Boston's forward-thinking approach to sustainable development. The Project will meet the challenge set forth in the City of Boston's Climate Action Plan – December 2007, as discussed in Section 1.3.1.

The Project is a Combined Heat and Power (CHP) facility. CHP is considered an Eco-friendly "green" technology recognized by the Massachusetts Green Communities Act and the Massachusetts Technology Collaborative as a cost effective, scalable method of producing electricity and utilizing waste heat to increase efficiency at the host site.

The benefits of this type of facility will extend beyond the BUMC Campus to the surrounding communities within and around downtown Boston. By allowing Boston University Medical Center to produce its own electricity and steam, the Project will help to alleviate the demand on the locally taxed energy infrastructure. This will improve delivery of existing energy service to the surrounding city communities. Additionally, the new facility will produce Boston University Medical Center's energy service using a cleaner, state-of-the-art process known as cogeneration. The local energy infrastructure that the BUMC Campus and BioSquare currently rely on to meet its energy demand employs conventional technologies that generate higher amounts of air emissions. Removing Boston University Medical Center's demand from this old technology will reduce the amount of air emissions and will greatly improve the environment for the surrounding city communities.

2.2.2 Energy System Summary

Combined heat and power is the simultaneous production of two useful forms of energy (electricity and thermal) from a single fuel source. The CHP system configured for the Energy Facility is comprised of two (2) 7.5 MW nominal capacity natural gas combustion turbine generators (CTGs) coupled with heat recovery steam generators (HRSGs). The HRSGs utilize the exhaust waste heat from the CTGs to produce steam. The CHP system for the Project is expected to have total efficiency of 72%. The overall efficiency of the Project is expected to be higher than the combination of the traditional utility grid power generation and the conventional steam heating plants.

It is estimated that the Energy Facility will average 434,338 MMBTU savings per year in utilizing CHP instead of purchasing utility produced electricity and steam. By utilizing the waste heat to produce steam, the overall efficiency is boosted. Over the course of thirty (30) years, it is estimated that 13,030,141 MMBTU's of energy will be saved through the use of cogeneration at the proposed Energy Facility.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

In summary, the proposed CHP for the Energy Facility has the following important benefits:

- Reduces Carbon Footprint – CHP generation reduces carbon emissions by over 20% over electricity purchased from the electrical utility and heat/chilling generated with traditional boilers and chillers.
- Energy Efficiency and Operating Cost Savings – The CHP plant has very high overall cycle efficiency. It is in excess of 70%, which results in large energy operating cost savings.
- Lower Air Emissions – Since the CHP plant operates at a higher overall cycle efficiency, it will have lower air emissions for the total energy produced (electrical plus thermal), as compared to the same total energy generated by the traditional electrical generating stations plus the conventional steam boiler plants.
- Best Available Control Technology - The proposed CHP plant is expected to employ Best Available Control Technology to further reduce the CO and NOx emissions.

2.2.3 Design

As evidenced by its initiatives undertaken through the Green Committee discussed in Section 1.3.1, Boston University Medical Center considers LEED qualification important and relative to the Project.

In addition to the “green” technology that the Energy Facility will employ, the Project is being designed to be consistent with many LEED credits. The Project is also consistent with Boston Green Building Credits for Modern Grid since the Project qualifies as a CHP facility and is in an area of taxed utility infrastructure.

The Project will comply with Article 37 of the Boston Zoning Code. Appendix C provides a draft LEED 2009 for New Construction (LEED 2009 NC) checklist that is being used to address other sustainability issues that may be attainable for this particular project.

The CHP facility and the cogeneration process will incorporate to the extent practical various sustainable design and energy recovery measures namely:

- Energy Efficient Building Envelope
- Energy Efficient Lighting System
- Process Waste Water Reclamation
- Waste Heat Recovery from Boiler Blow Down
- Waste Heat Recovery with Stack Economizers

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

2.3 Transportation

2.3.1 Vehicle Traffic

The proposed Energy Facility will require seven new full time employees and is not expected to have any impact on the surrounding transportation network: Albany Street, Massachusetts Avenue, or any other local or regional roadways. As the number of new employees required for the Energy Facility is minimal, person trips that are generated will be negligible. No new parking spaces are proposed.

2.3.2 Service and Loading

Trucks will need to access the Energy Facility periodically to service the equipment or for deliveries of new equipment and materials. All servicing for equipment and regular deliveries of materials to support ongoing operations will occur at the new loading dock at the south side of the Energy Facility. Servicing for equipment and deliveries will be scheduled to occur during off-peak traffic hours. Trucks will enter the Project site via the East Concord Street Extension from Albany Street to rear of the Energy Facility. Normal staff access and small material deliveries will occur at the loading dock of the Power Plant via the existing access from Albany Street.

When the north side of the Project site is developed for the Administration/Clinical Building, the existing loading dock for the Power Plant and the West Campus loading dock at the Menino Pavilion will be relocated to the south side of the Project site. At that time, trucks will access the Energy Facility south loading dock via the Southbound Frontage Road access and BioSquare Drive eliminating this function from Albany Street.

2.3.3 Bicycle Facilities

Boston University Medical Center has a very active bicycle program. Through TranSComm, the area's Transportation Management Association, sheltered and secured bicycle parking is offered at several locations on the BUMC Campus. The combination of bicycle racks and cages provides storage for a total of approximately 390 bicycles. See Figure 2-7, BUMC Campus Bicycle Facilities, for bicycle and shower facilities on the BUMC Campus.

A 2002 TranSComm survey of the Boston University Medical Center employees indicated that only about 1% of employees rode bicycles to work. As outlined in the recently submitted Boston University Medical Center IMP, TranSComm continues to provide amenities and programs to encourage cycling as a healthy, inexpensive and environmentally positive alternative to driving alone. There is also an active biking community on the BUMC Campus, the Bicycle User Group (BUG), which is a network of cyclists working together to continue to improve biking at the medical center.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS


For the Project, it is anticipated that new lockable bicycle racks for employees and staff will be installed adjacent to the Energy Facility where feasible.

2.3.4 Construction Period Impacts

During construction of the Energy Facility, the impacts to the transportation network and to the community are expected to be minor. The Project will be located several blocks from any residences thusly eliminating any impacts to them. The majority of the work will be staged on Boston University Medical Center property to minimize any effects on pedestrian, bicycle and vehicle operations in the area. See Section 2.5 – Construction Management Plan for more information on managing impacts. Prior to commencing construction, BMC will submit a Construction Management Plan (CMP) to the Boston Transportation Department for review and approval.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

Figure 2-7 BUMC Campus Bicycle Facilities



2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

2.4 Environmental Protection

2.4.1 Wind

The Energy Facility is designed to be of similar height and massing to buildings in the vicinity of the Project Site. The building itself will be approximately 100 feet above grade and the 6'-0" diameter stacks will be approximately 160 feet above grade.

Vertical deflection of upper winds usually results from buildings of 300 feet or more in height. As the height of the Project is approximately 100 feet above grade, it is not anticipated that the Project will deflect upper level winds. Channeling of airflows and induced turbulence usually occurs in high-density areas or urban street canyons. The Project does not create a canyon effect and is not expected to result in increased wind speeds.

Based on the height of the Project and its similar massing to surrounding buildings, the Project is not expected to cause significant material impacts to upper level or pedestrian level winds.

2.4.2 Daylight

The Project site is located within a dense urban environment surrounded by buildings of similar height and massing as the proposed Project. The Project is set back approximately 65 feet from the sidewalk and Albany Street (to the north). The site is immediately bordered to the east and west by buildings of similar height. Due to the existing configuration of the Project site, minimal impacts to daylight obstruction are anticipated.

2.4.3 Shadow

The proposed Project site is located in a densely urban area. As the proposed Energy Facility will be surrounded by and adjacent to structures of similar height and massing, any shadow impact will be comparable to the neighboring buildings. Additionally, due to the slender nature of the emissions stacks and the location and position of these stacks, they are less prominent. Net new shadow impacts from these elements are almost imperceptible and mostly fall on the roof of the Energy Facility itself. It is anticipated that the Energy Facility will not create significant net new shadow coverage on public ways or open spaces in the area during the time periods studied. See Appendix B for Shadow Study diagrams.

2.4.4 Solar Glare

It is not anticipated that the Project will include the use of reflective glass or other reflective materials on the building facades that would result in adverse impacts from reflected solar glare from the Project.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

2.4.5 Air Quality

2.4.5.1 Emissions Summary

The Project will allow Boston University Medical Center to generate 75% of its own electricity and 95% of its own steam. Cogeneration is a highly efficient method to produce steam and power, resulting in one of the lowest fossil fuel emissions and greenhouse gases. The facility, within one year of operation, will reduce net annual greenhouse gas emissions in excess of 18,000 metric tons of carbon dioxide. The cogeneration facility will consist of two Taurus 70 gas turbines and two duct burners to provide supplemental steam to the Boston University Medical Center distribution system. The gas turbines and duct burners will be fueled by natural gas under normal operating conditions.

The facility will be a minor source of air emissions and will need to file an Environmental Results Program form for a Non-Emergency Turbine and a Non Major Comprehensive Air Plans Approval application for its duct burners. The turbine and duct burner will be designed to meet Massachusetts Department of Environmental Protection's (MassDEP) requirements for Best Available Control Technology. As noted in Section 2.4.5.4, the cogeneration facility demonstrates compliance with the National Ambient Air Quality Standards. Furthermore, the Project will not result in material increases in vehicle trip generation and therefore air quality impacts associated with vehicle emissions will be minimal.

Turbine and Duct Burner Emissions

The Project proposes two Solar Taurus 70 turbines that exhaust to a Heat Recovery Steam Generator (HRSG). Each of the dual fueled-fired turbines will have a heat input of 85.9 MMBtu/hr. The HRSG is capable of supplementary duct firing to produce additional steam. Each of the natural gas-fired duct burners will have a heat input of 129.2 MMBtu/hr.

The turbines will be capable of firing natural gas or Ultra Low Sulfur Diesel (ULSD). Natural gas will be used under normal operating conditions. ULSD would only be used to operate the turbines as an emergency fuel in the event of starting the turbines during a grid power outage, known as a "black start". The turbines will be limited by capacity of the ULSD tank to firing a maximum of 14 hours of operation using the alternate fuel.

The turbines will be equipped with Selective Catalytic Reduction (SCR) to minimize Oxides of Nitrogen (NO_x) emissions and an Oxidation Catalyst to minimize Carbon Monoxide (CO) and Volatile Organic Compound (VOC) emissions. Emissions of Particulate Matter (PM₁₀/PM_{2.5}) and Sulfur Dioxide (SO₂) are minimized by efficient combustion controls and choice of natural gas and ULSD as the fuels. The emissions from these units for each fuel are presented in Table 2-1 on the next page.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

Table 2-1 Short Term Turbine and Duct Burner Emissions

Pollutant	Turbine Only		Turbine w/ Duct Firing		Units
	Natural Gas	ULSD	Natural Gas	ULSD	
NO _x	2.5	5	2.5	5	Ppm @ 15% O ₂
CO	5	5	5	5	ppm @ 15% O ₂
VOC	3	12	3	12	ppm @ 15% O ₂
PM ₁₀	0.021	0.039	0.014	0.021	lb/MMBtu
PM _{2.5}	0.021	0.039	0.011	0.018	lb/MMBtu
SO ₂	0.0006	0.0015	0.0006	0.0010	lb/MMBtu
NH ₃	2	2	2	2	ppm @ 15%O ₂

These emissions will comply with the turbine emission limits established by DEP's air regulations at 310 CMR 7.26(43) or the cogeneration requirements at 310 CMR 7.26(45).

Energy Facility Annual Emissions

The Energy Facility turbines will operate on natural gas with a maximum limit of 720 hours per year of ULSD firing for black start conditions. The Energy Facility's emissions limits for the two turbines and HRSG systems are as follows:

Table 2-2 Estimated Annual Emissions

Pollutant	Energy Facility (tpy)
NO _x	19.7
CO	22.1
VOC	9.5
SO ₂	1.2
PM ₁₀	29.0
PM _{2.5}	23.0

2.4.5.2 Background Air Quality

To estimate background pollutant levels representative of the area, the most recent monitoring values were obtained from the following United States Environmental Protection Agency (EPA) website. Data for 2006 through 2008 were acquired from <http://www.epa.gov/air/data/>. DEP guidance specifies the use of the latest three years of available monitoring data from within 10 km of the project site.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

Background concentrations were determined from the closest available monitoring stations to the Energy Facility. The closest monitoring site is located at Harrison Avenue in Boston, approximately 0.6 miles southwest of the BUMC Campus. See Figure 2-8, DEP Monitoring Station. All pollutants are monitored at Harrison Avenue, i.e., SO₂, CO, NO₂, PM-10, and PM-2.5.

A summary of the background air quality concentrations based on the 2006-2008 data is presented in Table 2-3. For short-term averages (24 hours or less), the highest of the second-highest or the yearly observations will be estimated to be the background concentration, with the exception of PM_{2.5} 24-hour where the 98th percentile concentration was used, consistent with the short-term ambient air quality standards. The short-term ambient air quality standards are not to be exceeded more than once per year. For long-term averages, the highest yearly observation was used as the background concentration.


Table 2-3 Observed Ambient Air Quality Concentrations at Harrison Avenue and Selected Background Levels

	Averaging Period	2006	2007	2008	Background Level	NAAQS
PM-10* (µg/m ³)	24-Hour	38/32/30/28	40/24/23/22	28/27/26/25	30**	150
	Annual	16	14	14	16	50
PM-2.5 (µg/m ³)	24-Hour	27.3	31.5	28.0	28.9***	35
	Annual	9.69	10.48	10.08	10.1***	15
CO (µg/m ³)	1-Hour	3,420	2,280	1,710	3,420	40,000
	8-Hour	1,938	1,368	1,026	1,938	10,000
SO ₂ (µg/m ³)	3-Hour	49.8	57.6	49.8	57.6	1300
	24-Hour	31.4	34.1	31.4	34.1	365
	Annual	7.9	7.9	5.2	7.9	80
NO ₂ (µg/m ³)	1-Hour	112.8	135.4	116.6	135.4	188
	Annual	35.7	37.6	37.6	37.6	100

Notes: * Four highest 24-Hour averages during each calendar year.
 ** Background level for PM10 is the 4th highest over three years.
 *** Background level for PM2.5 is the average over three years.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

Figure 2-8 DEP Monitoring Station



Boston University Medical Center Boston, Massachusetts



DEP Monitoring Station

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

2.4.5.3 Air Quality Modeling

The EPA *Guideline on Air Quality Models* (EPA, 2005) recommends that an air quality dispersion modeling analysis be performed to assess the pollutant impact in the vicinity of the project applying for a permit. Air quality dispersion modeling was used to document that project emissions will not cause or contribute to any violation of applicable ambient air quality standards. Methods and results are presented in this Section.

Air Quality Model Selection

The EPA approved air quality model used for this analysis is the AERMOD model (version 09292). Using the regulatory default options, AERMOD was used to identify maximum impact concentrations. The AERMODView graphical user interface (GUI) Version 6.4, created by Lakes Environmental, was used to facilitate model setup and post-processing of data.

The AERMOD model is a steady state plume model, using Gaussian distributions that calculate concentrations at each receptor for every hour in the year. The model is designed for rural or urban applications and can be used with a rectangular or polar system of receptors that are allowed to vary with terrain. AERMOD is designed to operate with two preprocessor codes: AERMET processes meteorological data for input to AERMOD, and AERMAP processes terrain elevation data and generates receptor information for input to AERMOD. The AERSURFACE program, a tool provided by EPA, was used to assess the surface characteristics near the meteorological observation site and those data used as input to AERMET. The AERMOD model was selected for the air quality modeling analysis because of several model features that properly simulate the proposed facility environs, including the following:

- Concentration averaging time ranging from one hour to one year;
- Estimating air quality impacts associated with building downwash; and
- Use of actual representative hourly average meteorological data.

The AERMOD model incorporates the Plume Rise Model Enhancements (PRIME), the latest EPA building downwash algorithm for the improved treatment of building downwash. PRIME can also account for the stack placement relative to the building thereby allowing for the ability to calculate impacts in the cavity region near the stack.

A complete technical description of the AERMOD model may be found in the *User's Guide for AERMOD* (EPA, 2004).

Receptor Grid

A nested Cartesian grid of receptors was generated with spacing of 50 meters in a 600 meter by 600 meter bounding box centered on the stacks, 100 meter spacing out to 1000 meters, and 500 meter spacing out to 5 km.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

Terrain around the immediate site is relatively flat. The terrain elevation for each receptor was obtained electronically from USGS digital terrain data. The National Elevation Dataset (NED), with a resolution of one arc-second (approximately 30 meters) was processed using the AERMAP program.

AERMOD Model Options

The Boston University Medical Center sources were modeled hour-by-hour using refined modeling techniques for the five years of hourly meteorological data from Logan International Airport. The AERMOD model was used with the regulatory default option set. This automatically selects the EPA recommended options for stack tip downwash, effects of elevated terrain, calm and missing data processing routines, and uses the upper-bound concentration estimates for sources influenced by building downwash from super-squat buildings. Building downwash was modeled using the building dimensions output from BPIP-Prime.

2.4.5.4 AERMOD Results

Predicted concentrations for the combined impact from both combustion turbines are shown in Table 2-4. Modeled impacts were added to ambient measured background levels to document compliance with the National Ambient Air Quality Standards (NAAQS). These predicted concentrations occurred approximately 250 meters to the west of the stacks for each pollutant and averaging time, with the exception of the 1-hour CO impact which was predicted to occur approximately 255 meters to the west-southwest of the stacks.

As documented in Table 2-4 on the next page, the Project complies with the NAAQS for all pollutants and averaging times.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

Table 2-4 Comparison of Project Predicted AERMOD Results with the National Ambient Air Quality Standard

Pollutant	Averaging Period	Project Predicted Concentration ($\mu\text{g}/\text{m}^3$)	Receptor Location (UTM-E, UTM-N, Elev.) (meters)	Period	Monitored Background Concentration ($\mu\text{g}/\text{m}^3$)	Total Impact ($\mu\text{g}/\text{m}^3$)	NAAQS ($\mu\text{g}/\text{m}^3$)	Percent of NAAQS (%)
PM-10	24-Hr H2H	6.72	329099, 4688957, 4.7	10/12/04	30	36.7	150	24%
PM-2.5	24 Hr H8H	3.94	329099, 4688957, 4.7	12/7/04	28.9	32.8	35	94%
	Annual	0.49	329099, 4688957, 4.7	2004	10.1	10.6	15	71%
NO ₂	1-Hr H2H*	17.8	329099, 4688907, 4.9	7/12/05 hr 14	135.4	153.2	188	81%
	Annual	0.42	329099, 4688957, 4.7	2004	37.6	38.0	100	38%
SO ₂	3-Hr H2H	5.28	329099, 4688957, 4.7	7/5/08 hr 15	57.6	62.9	1300	5%
	24-Hr H2H	0.29	329099, 4688957, 4.7	7/5/08	34.1	34.4	365	9%
	Annual	0.026	329099, 4688957, 4.7	2004	7.9	7.9	80	10%
CO	1-Hr H2H	10.73	329099, 4688907, 4.9	7/12/05 hr 14	3,420	3,431	40,000	9%
	8-Hr H2H	7.05	329099, 4688957, 4.7	11/30/05 hr 8	1,938	1,945	10,000	19%

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

2.4.6 Noise

2.4.6.1 Introduction

This section includes a noise analysis for the Project, including a noise-monitoring program to determine existing noise levels and an estimate of future noise levels when the Project is in operation. The analysis indicates that predicted noise levels from Project mechanical equipment will be below the most stringent City of Boston Noise Zoning requirements for nighttime and daytime residential zones, and well below existing measured baseline noise levels in the area.

The Project site is located proximate to I-93 and the Massachusetts Avenue Connector which are the sources for much of the ambient noise in the area. In addition, the ambient noise levels around the Project site are elevated due to the urban nature of the area. As discussed in detail below, the noise modeling analysis demonstrates that the noise levels from the Project will be below Massachusetts Department of Environmental Protection and City of Boston standards in relationship to background noise conditions.

2.4.6.2 Noise Terminology

There are several ways in which sound (noise) levels are measured and quantified. All of them use the logarithmic decibel (dB) scale. The following information defines the noise measurement terminology used in this analysis.

The decibel scale is logarithmic to accommodate the wide range of sound intensities found in the environment. A property of the decibel scale is that the sound pressure levels of two separate sounds are not directly additive. For example, if a sound of 50 dB is added to another sound of 50 dB, the total is only a three-decibel increase (to 53 dB), not a doubling to 100 dB. Thus, every three dB change in sound levels represents a doubling or halving of sound energy. Related to this is the fact that a change in sound levels of less than three dB is imperceptible to the human ear.

Another property of decibels is that if one source of noise is 10 dB (or more) louder than another source, then the total sound level is simply the sound level of the higher source. For example, a source of sound at 60 dB plus another source of sound at 47 dB is 60 dB.

The sound level meter used to measure noise is a standardized instrument. It contains “weighting networks” to adjust the frequency response of the instrument to approximate that of the human ear under various circumstances. One network is the A-weighting network (there are also B- and C-weighting networks). The A-weighted scale (dBA) most closely approximates how the human ear responds to sound at various frequencies. Sounds are frequently reported as detected with the A-weighting network of the sound level meter. A-weighted sound levels emphasize the middle frequency (i.e., middle pitched – around 1,000

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

Hertz sounds), and de-emphasize lower and higher frequency sounds. A-weighted sound levels are reported in decibels designated as “dBA.”

Because the sounds in our environment vary with time they cannot simply be described with a single number. Two methods are used for describing variable sounds. These are exceedance levels and the equivalent level, both of which are derived from a large number of moment-to-moment A-weighted sound level measurements. Exceedance levels are values from the cumulative amplitude distribution of all of the sound levels observed during a measurement period. Exceedance levels are designated L_n , where ‘n’ can have a value of 0 to 100%. For example:

- L_{90} is the sound level in dBA exceeded 90% of the time during the measurement period. The L_{90} is close to the lowest sound level observed. It is essentially the same as the residual sound level, which is the sound level observed when there are no obvious nearby intermittent noise sources.
- L_{50} is the median sound level: the sound level in dBA exceeded 50% of the time during the measurement period.
- L_{10} is the sound level in dBA exceeded only 10% of the time. It is close to the maximum level observed during the measurement period. The L_{10} is sometimes called the intrusive sound level because it is caused by occasional louder noises like those from passing motor vehicles.
- L_{eq} , the equivalent level, is the level of a hypothetical steady sound that would have the same energy (i.e., the same time-averaged mean square sound pressure) as the actual fluctuating sound observed. The equivalent level is designated L_{eq} and is also A-weighted. The equivalent level represents the time average of the fluctuating sound pressure, but because sound is represented on a logarithmic scale and the averaging is done with linear mean square sound pressure values, the L_{eq} is mostly determined by occasional loud, intrusive noises.
- The maximum sound level (designated L_{max}) is the greatest sound level measured within a stated time interval.

By using various noise metrics it is possible to separate prevailing, steady sounds (the L_{90}) from occasional, louder sounds (L_{10}) in the noise environment or combined average levels (L_{eq}). This analysis of sounds expected from the Project treats all noises as though they will be steady and continuous and hence the L_{90} exceedance level was used. In the design of noise control treatments it is essential to know something about the frequency spectrum of the noise of interest. Noise control treatments do not function like the human ear, so simple A-weighted levels are not useful for noise-control design. The spectra of noises are usually stated in terms of octave band sound pressure levels, in dB, with the octave frequency bands being those established by standard. To facilitate the noise-control design process,

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

the estimates of noise levels in this analysis are also presented in terms of octave band sound pressure levels.

Baseline noise levels were measured in the vicinity of the proposed buildings and were compared to predicted noise levels that were based on standard engineering practice or information provided by the manufacturers of representative mechanical equipment. The predicted noise levels were compared to the City of Boston Zoning District Noise Standards, and the Massachusetts Department of Environmental Protection (MassDEP) Noise Policy.

2.4.6.3 Noise Regulations and Criteria

The primary set of regulations relating to the potential increase in noise levels is the City of Boston Zoning District Noise Standards (City of Boston Code – Ordinances: Section 16–26 Unreasonable Noise and City of Boston Air Pollution Control Commission Regulations for the Control of Noise in the City of Boston). Results of the baseline ambient noise level survey and the modeled noise levels were compared to the City of Boston Zoning District Noise Standards. Separate regulations within the Standard provide criteria to control different types of noise. Regulation 2 is applicable to the effects of the completed proposed buildings and was considered in this noise study. Table 2-5 includes the Zoning District Standards.

The Massachusetts Department of Environmental Protection (MassDEP) regulates community noise by its Noise Policy: DAQC policy 90-001. The MassDEP policy limits source sound levels to a 10-dBA increase in the ambient measured noise level (L_{90}) at the Project property line and at the nearest residences. The policy further prohibits pure tone conditions – when any octave band center frequency sound pressure level exceeds the two adjacent center frequency sound pressure levels by three decibels or more.

Table 2-5 City of Boston Zoning District Noise Standards, Maximum Allowable Sound Pressure Levels

Octave Band Center Frequency (Hz)	Residential Zoning District		Residential-Industrial Zoning District		Business Zoning District	Industrial Zoning District
	Daytime (dB)	All Other Times (dB)	Daytime (dB)	All Other Times (dB)	Anytime (dB)	Anytime (dB)
31.5	76	68	79	72	79	83
63	75	67	78	71	78	82
125	69	61	73	65	73	77
250	62	52	68	57	68	73
500	56	46	62	51	62	67
1000	50	40	56	45	56	61
2000	45	33	51	39	51	57
4000	40	28	47	34	47	53
8000	38	26	44	32	44	50

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

A-Weighted (dBA)	60	50	65	55	65	70
Notes:	<ul style="list-style-type: none"> ◆ Noise standards are extracted from Regulation 2.5, City of Boston Air Pollution Control Commission, "Regulations for the Control of Noise in the City of Boston", adopted December 17, 1976. ◆ All standards apply at the property line of the receiving property. ◆ dB and dBA based on a reference pressure of 20 micropascals. ◆ Daytime refers to the period between 7:00 am and 6:00 pm daily except Sunday. 					

2.4.6.4 Existing Conditions

Baseline Noise Environment

An ambient noise level survey was conducted to characterize the existing "baseline" acoustical environment in the vicinity of the Project. Existing noise sources in the vicinity of the Project include: vehicular traffic (including trucks) on the local roadways; pedestrian traffic; and mechanical equipment located on the surrounding buildings.

Noise Measurement Locations

The selection of the sound monitoring receptor locations was based upon a review of the current land use in the area of the Project Site. Noise was measured at six locations in the vicinity of the Project site to establish background noise conditions. The measurement locations are depicted on Figure 2-9 and are described below.

- Location 1 is in a Boston Medical Center parking lot on East Brookline Street. The receptor was located south of the parking lot gate, adjacent to the residential property at 81 East Brookline Street.
- Location 2 is near the residential property at 107 East Brookline Street.
- Location 3 is near the Boston Medical Center Menino Pavilion entrance on Albany Street.
- Location 4 is near the Hampton Inn at 811 Massachusetts Avenue.
- Location 5 is near the intersection of Harrison Avenue and Public Alley 716 (between Massachusetts Avenue and East Springfield Street) which is representative of the residential area north of Harrison Avenue.
- Location 6 is near the residential property at 39 Worcester Square.

Noise Measurement Methodology

Short-term sound level measurements were made at all six locations for 20 minutes per location during daytime hours (11:00 am to 4:00 pm) on January 07, 2010, and nighttime hours (12:00 am to 4:00 am) on January 08, 2010. Since noise impacts are greatest at night when existing noise levels are lowest, the study was designed to measure community

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

noise levels under conditions typical of a “quiet period” for the area. Daytime measurements were scheduled to exclude peak traffic conditions.

In addition to the short-term sampling data, one continuous programmable sound level meter was placed at Location 1 on January 06, 2010. This monitor continuously measured and stored hourly sound level statistics for 36 consecutive hours in order to confirm that the short-term sampling was indeed representative of the lowest sound levels. This monitor ran from 3:00 P.M. Wednesday, January 06, 2010, until 3:00 AM on Friday, January 08, 2010. Field personnel periodically checked on the integrity of the continuous equipment, and observed and recorded the noise sources at the monitoring location.

Short-term sound levels were measured at a height of five feet above the ground while the continuous sound level was measured at a height of six feet above the ground. Both continuous and short-term sound levels were measured at publicly accessible locations. The measurements were generally made under low wind conditions and with dry roadway surfaces. Wind speed measurements were made with a Davis Instruments TurboMeter electronic wind speed indicator, and temperature and humidity measurements were made using a psychrometer. Unofficial observations about meteorology or land use in the community were made solely to characterize the existing sound levels in the area and to estimate the noise sensitivity at properties near the proposed Project.

Measurement Equipment

Short-term measurements were taken with a CEL Instruments Model 593.C1 Precision Sound Level Analyzer equipped with a CEL-257 Type 1 Preamplifier, a CEL-250 half-inch electret microphone, and a four-inch foam windscreen. Both short-term broadband and octave band ambient sound pressure level data were collected. This instrument meets the “Type 1 - Precision” requirements set forth in American National Standards Institute (ANSI) S1.4 for acoustical measuring devices. The microphone was tripod-mounted at a height of five feet above ground, and the meter was set to the “slow” response. Statistical descriptors (L_{eq} , L_{90} , etc.) were calculated for each 20-minute sampling period. Octave band levels for this study correspond to the same data set processed for the broadband levels. The measurement equipment was calibrated in the field before and after the surveys with a CEL-110/1 acoustical calibrator, which meets the standards of IEC 942 Class 1L and ANSI S1.40-1984.

A Larson Davis model 812 Sound Level Meter was used for the continuous monitoring. This meter was equipped with a Larson Davis PRM828 Preamplifier, a PCB Piezotronics 337B02 microphone, and a foam windscreen. This instrument meets Type 1 ANSI S1.4-1983 standards for sound level meters. The microphone was mounted at a height of six feet above ground, and the meter was set to the “slow” response. The model 812 has data logging capability and was programmed to log statistical data every hour for the following parameters: L_1 , L_{10} , L_{50} , L_{90} , L_{max} , L_{min} , and L_{eq} . The measurement equipment was calibrated


2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

in the field before and after the surveys with a CEL-110/1 acoustical calibrator, which meets the standards of IEC 942 Class 1L and ANSI S1.40-1984.

Both instruments have been calibrated and certified as accurate to standards set by the National Institute of Standards and Technology by an independent laboratory within the past 12 months.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

Figure 2-9 Sound Level Measurement Locations



Boston University Medical Center Boston, Massachusetts

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

Baseline Ambient Noise Levels

The existing ambient noise environment for the short-term 20-minute measurements is impacted primarily by mechanical equipment located on surrounding buildings and by vehicular traffic on nearby roadways, including Albany Street, Harrison Avenue, and Massachusetts Avenue. Baseline short-term 20-minute noise monitoring results are presented in Table 2-6, and summarized below.

- The daytime residual background (L_{90}) measurements ranged from 54 to 65 dBA;
- The nighttime residual background (L_{90}) measurements ranged from 49 to 62 dBA;
- The daytime equivalent level (L_{eq}) measurements ranged from 61 to 74 dBA; and
- The nighttime equivalent level (L_{eq}) measurements ranged from 51 to 67 dBA.

The existing ambient noise environment for the long-term measurement is impacted primarily by mechanical equipment located on surrounding buildings, vehicular traffic entering and exiting the adjacent parking lot and parking garage, and vehicular traffic on nearby roadways, including Albany Street, Harrison Avenue, Massachusetts Avenue, and East Brookline Street. Baseline long-term noise monitoring results are presented in Table 2-7, plotted on Figure 2-10, and summarized below.

- The long-term residual background (L_{90}) measurements ranged from 51 to 55 dBA;
- The long-term equivalent level (L_{eq}) measurements ranged from 52 to 65 dBA.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

Table 2-6 Baseline Ambient Noise Measurements

Location and Period	Start Time	L ₁₀ (dBA)	L ₅₀ (dBA)	L ₉₀ (dBA)	L _{eq} (dBA)	L _{max} (dBA)	Octave Band Center Frequency (Hz)								
							32 L ₉₀ (dB)	63 L ₉₀ (dB)	125 L ₉₀ (dB)	250 L ₉₀ (dB)	500 L ₉₀ (dB)	1000 L ₉₀ (dB)	2000 L ₉₀ (dB)	4000 L ₉₀ (dB)	8000 L ₉₀ (dB)
Loc 1 Day	1:47 PM	65	58	57	62	-	66	62	59	57	55	51	47	37	28
Loc 2 Day	11:25 AM	68	60	57	66	81	66	64	59	58	56	51	45	34	22
Loc 3 Day	3:02 PM	74	68	65	71	-	71	71	67	64	63	61	56	48	38
Loc 4 Day	2:30 PM	76	68	64	74	92	74	75	70	62	59	59	55	48	40
Loc 5 Day	12:31 PM	71	65	61	68	84	72	71	65	59	57	56	53	47	40
Loc 6 Day	1:12 PM	64	57	54	61	76	65	63	57	53	52	49	44	37	30
Loc 1 Night	2:39 AM	52	52	51	52	56	58	57	55	53	51	45	38	28	19
Loc 2 Night	2:09 AM	57	55	55	56	65	64	60	57	57	55	48	41	32	21
Loc 3 Night	12:19 AM	69	64	62	67	84	66	64	65	60	59	57	53	44	33
Loc 4 Night	12:47 AM	68	61	57	65	84	64	64	62	55	53	52	48	39	31
Loc 5 Night	1:15 AM	63	56	53	60	75	63	59	56	53	51	48	44	36	33
Loc 6 Night	1:41 AM	53	49	49	51	63	58	56	51	50	48	43	37	26	16

Notes:

- Daytime weather: Temperature = 39° F, RH = 51%, skies sunny, winds 0-4 mph.
Nighttime weather: Temperature = 30° F, overcast skies, winds 0-8 mph.
- Road Surfaces were dry during all periods.
- All sampling periods were approximately 20 minutes duration.
- Daytime measurements were collected on January 07, 2010.
Nighttime measurements were collected on January 08, 2010.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

Table 2-7 Continuous Ambient Noise Measurement


Date	Start Time	L ₉₀ (dBA)	L _{eq} (dBA)	L _{max} (dBA)
January 6, 2010	3:00 PM	53	59	83
January 6, 2010	4:00 PM	53	58	80
January 6, 2010	5:00 PM	52	56	77
January 6, 2010	6:00 PM	53	55	74
January 6, 2010	7:00 PM	52	55	77
January 6, 2010	8:00 PM	52	54	64
January 6, 2010	9:00 PM	52	53	64
January 6, 2010	10:00 PM	52	59	80
January 6, 2010	11:00 PM	52	60	83
January 7, 2010	12:00 AM	51	55	77
January 7, 2010	1:00 AM	51	56	80
January 7, 2010	2:00 AM	51	52	63
January 7, 2010	3:00 AM	51	55	77
January 7, 2010	4:00 AM	52	53	62
January 7, 2010	5:00 AM	52	57	73
January 7, 2010	6:00 AM	54	63	81
January 7, 2010	7:00 AM	55	64	85
January 7, 2010	8:00 AM	55	65	83
January 7, 2010	9:00 AM	54	62	81

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

Date	Start Time	L ₉₀ (dBA)	L _{eq} (dBA)	L _{max} (dBA)
January 7, 2010	10:00 AM	54	63	81
January 7, 2010	11:00 AM	54	65	84
January 7, 2010	12:00 PM	53	60	82
January 7, 2010	1:00 PM	54	62	81
January 7, 2010	2:00 PM	55	64	87
January 7, 2010	3:00 PM	53	56	74
January 7, 2010	4:00 PM	53	57	83
January 7, 2010	5:00 PM	53	56	69
January 7, 2010	6:00 PM	52	56	82
January 7, 2010	7:00 PM	52	55	72
January 7, 2010	8:00 PM	51	54	74
January 7, 2010	9:00 PM	51	54	72
January 7, 2010	10:00 PM	51	53	69
January 7, 2010	11:00 PM	52	54	69
January 8, 2010	12:00 AM	51	54	76
January 8, 2010	1:00 AM	51	52	62
January 8, 2010	2:00 AM	51	52	60

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

Figure 2-10 Baseline Long-Term Noise Monitoring



2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

Overview of Potential Project Noise Sources

This section provides a detailed discussion of the primary components of the Energy Facility and their associated reference sound level data. The key component – gas turbine generator – has been selected and manufacturer's sound level data for this component is used in the analysis. As is typical for a power project, certain components are selected and purchased by the EPC contractor later in the Project development effort. Accordingly, the reference sound level data used for the noise modeling includes the primary vendor data, as well as representative data from comparable projects, field measurements of similar equipment made at existing plants, and values from the literature based on engineering parameters. Several non-major noise sources which might otherwise have been included in the analysis were not modeled since they will be inside the Energy Facility building, and will be insignificant.

Table 2-8 summarizes the sound level data for the equipment described in the following sections. These sound levels constitute the "Base Case" which represents a reasonably well-controlled package, including enclosures, rated at "85 dBA at 1 meter." The primary sources of noise from the Energy Facility are the gas turbine generator and associated air intake and exhaust, wet mechanical cooling tower, and the rooftop air intake/exhaust fans.

Gas Turbine Generator Package

Two Solar Taurus 70 turbines are proposed. These packages will consist of both a gas turbine and an AC generator module. Each unit is rated at approximately 7 MW. The gas turbine will be housed within an acoustical enclosure, and located within the Energy Facility building. According to the manufacturer, these units will not exceed 85 dBA at 3 feet.

Gas Turbine Air Inlet

Each gas turbine generator package is equipped with an air inlet filter. Each air inlet filter will be located within Level 2 of the Energy Facility building. Fresh air will be drawn in through a louver in the north wall facing Albany Street, and ducted through a combustion air inlet plenum. The elevation of the air inlet filter ranges from approximately 38 feet above ground level (bottom of louver) to 59 feet above ground level (top of louver). Sound from each air inlet will be reduced by two devices – an inlet silencer and the pulse-cleaning cross-flow system. Air inlet and sound level reduction data were provided by Solar from comparable projects.

Gas Turbine Stack Exhaust

Each gas turbine generator package will exhaust through an SCR and HRSG, and then up an exhaust stack. Sound levels radiating out the top of the stack approximately 160 feet above ground level were included as an elevated sound source. Sound from the unsilenced gas turbine exhaust will be reduced by both the SCR and HRSG prior to exiting the stack.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

Exhaust data were provided by Solar while the reduction from the SCR and HRSG were estimated based on other vendor data.

Cooling Tower

A 2-cell wet mechanical cooling tower is proposed for the rooftop of the Energy Facility building. A typical cooling tower for this type of application is the Marley NC8403QAN2 which is approximately 12 feet high. Marley provided sound power level data for this source.

Gas Compressors

Two natural gas compressors will be located on the rooftop of the Energy Facility building. These units will be located inside an enclosure to reduce sound levels. Sound level data are not currently available for the compressors. For this analysis, sound level data from another power plant project using similarly sized gas compressors in an enclosure were used in the modeling.

Exhaust/Supply Air Fans

Three exhaust air fans and three supply air fans will be mounted on the roof of the Energy Facility building. Sound level data for typical fans were used in the modeling.

Insignificant Sources

Several sources were considered as part of the sound modeling but were not included as they were insignificant as compared to the primary sources. These included:

- ◆ Lube oil cooler (minor source and inside building);
- ◆ Transformers (inside building);
- ◆ Gas metering station.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

Table 2-8 Sound Power or Sound Pressure Level Data for Project Noise Modeling – Base Case (per unit) (dB)

Plant Component	No.	Ref. distance	dBA	Octave Band Center Frequency (Hz)								
				31.5	63	125	250	500	1k	2k	4k	8k
Solar Taurus 70 Air Inlet (unsilenced)	2	50 ft	127	79	85	91	92	93	95	98	126	118
Combustion air inlet – silencer insertion loss	2	NA	NA	1	3	7	11	20	40	55	53	41
Combustion air inlet – pulse-cleaner insertion loss	2	NA	NA	0	3	5	7	12	9	18	17	24
Solar Taurus 70 gas turbine generator – enclosed package	2	3 ft	85	96	89	86	83	81	80	78	75	70
Solar Taurus 70 gas turbine exhaust (unsilenced)	2	Lw	130	123	126	123	127	129	125	119	112	99
SCR/HRSG – noise reduction for turbine exhaust	2	NA	NA	17	23	29	35	45	55	55	51	37
Wet mechanical cooling tower	1	Lw	101	--	105	103	104	99	94	90	86	80
Gas compressors on roof	2	Lw	91	88	88	85	83	85	77	85	84	84
Exhaust air fans on roof	3	Lw	117	--	110	109	109	112	112	110	107	107
Supply air fans on roof	3	Lw	112	--	105	104	104	109	108	105	102	100

Lw = sound power level.

NA= Not applicable to sound power level, or insertion loss.

-- = Data unavailable from the manufacturer

Modeling Methodology

Anticipated noise impacts associated with the Project were predicted at the nearest residences around the Project site using the CadnaA noise calculation software. This software uses the ISO 9613-2 industrial noise calculation methodology. CadnaA allows for octave band calculation of noise from multiple noise sources, as well as for computation of diffraction around building edges and multiple reflections off parallel buildings and solid ground areas. In this manner, all significant noise sources and geometric propagation effects are accounted for in the noise modeling.

2.4.6.6 Conclusions

Predicted mechanical equipment noise levels from the Project at each receptor location, taking into account attenuation due to distance, structures, and noise control measures, are all below the MassDEP criteria of 10 dBA over the quietest nighttime sound levels. The predicted Project-generated exterior sound levels are expected to range from 20 dBA to 49 dBA at nearby receptors. The predicted sound levels from Project-related equipment are within the most stringent nighttime residential zoning limits for the City of Boston (50 dBA or less) at closest residential receptors. Locations 3 (Menino Pavilion) and the Energy Facility courtyard are part of the BUMC Campus and not considered off-site. It should be noted that the existing ambient background levels already exceed 50 dBA at most locations studied.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

The Project's mechanical equipment will not create any pure tone conditions when combined with existing middle of the night background sound levels. The results of the modeling, including mitigation, are shown in Table 2-9 (MassDEP criteria) and Table 2-10 (Boston criteria).

The results indicate that noise levels due to the Project at the various receptor locations are below the most stringent City of Boston Noise Zoning requirements for a nighttime residential zone for street-level receptors, and they are below existing measured nighttime baseline noise levels. As shown in Table 2-9, the increase in sound level is expected to be zero dBA. Therefore, the results of the analysis indicate that the proposed Project can operate without significant impact on the existing acoustical environment.

Table 2-9 Comparison of Future Predicted Nighttime Sound Levels with Existing Background – MassDEP Criteria

Location	Lowest Existing L ₉₀ -- Nighttime (dBA)	Project-Generated Sound Levels (dBA) ¹	Future L ₉₀ – Nighttime Total (dBA)	Increase (dBA)
Location 1 – East Brookline Ave	51	20	51	0
Location 2 - East Brookline Ave.	55	27	55	0
Location 3 – Menino Pavilion (on-site)	62	45	62	0
Location 4 – Hampton Inn	57	29	57	0
Location 5 – Harrison Ave/Mass Ave	53	27	53	0
Location 6 – Worcester Square	49	32	49	0
BMC Energy Facility Courtyard (on-site)	62 ²	49	62	0

1. Assumes equipment operates continuously.
2. Use Location 3 measurement as representative background.

Table 2-10 Comparison of Future Predicted Nighttime Sound Levels Incorporating Appropriate Mitigation to City of Boston Criteria – Off-site Locations

Location	A-wtd (dBA)	Octave Band Center Frequency (Hz)								
		31.5 ¹ L ₉₀ (dB)	63 L ₉₀ (dB)	125 L ₉₀ (dB)	250 L ₉₀ (dB)	500 L ₉₀ (dB)	1000 L ₉₀ (dB)	2000 L ₉₀ (dB)	4000 L ₉₀ (dB)	8000 L ₉₀ (dB)
Location 1	20	--	37	28	23	16	8	8	0	0
Location 2	27	--	41	31	24	23	17	22	13	0
Location 4	29	--	45	35	29	26	19	23	16	0
Location 5	27	--	42	34	31	24	16	13	4	0
Location 6	32	--	44	38	36	30	22	20	9	0
City of Boston - Nighttime Limits	50	68	67	61	52	46	40	33	28	26

1. Predictive 31.5 Hz octave band level cannot be calculated due to absence of manufacturer's data (see Table 2-8.)

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

2.4.7 Flood Hazard Zones / Wetlands

The Federal Emergency Management Agency (FEMA) Flood Insurance Rate Map (FIRM) for the site located in the City of Boston - Community Panel Number 250286 0010 C indicates the FEMA Flood Zone Designations for the site area. The map shows that the Project is located in a Zone C, Area of Minimal Flooding. The site does not contain wetlands.

2.4.8 Geotechnical/Groundwater

2.4.8.1 Subsurface Conditions

Generally the site is overlain with approximately 8 to 10 ft of miscellaneous fill. The fill unit is underlain by relatively soft organic silt and peat (15 to 20 ft thick layer). Naturally deposited marine clay is present approximately 25 to 30 ft below grade. These deposits are comparatively thick and underlain by a glaciomarine deposit and glacial till. Bedrock is approximately 125 to 175 ft below the ground surface.

Groundwater level measurements obtained at monitoring wells installed on and in the vicinity of the Project have been reviewed to develop an understanding of groundwater conditions and considerations for below-grade construction design and planning. Groundwater levels vary with season and other local influences, and groundwater levels ranging between three and eight feet below grade (El. 9 to 14) were recorded in the past.

2.4.8.2 Foundation Methodology

The surficial fill and organic soils are not suitable for foundation support. It is anticipated that the proposed foundations would need to extend at least to the naturally deposited, inorganic marine clay or glacial till/bedrock, depending upon the structure loads. For the one basement level design being considered, foundations that are feasible include drilled shafts, piles, and pressure injected footings.

2.4.8.3 Excavation Support

For construction of the basement space, a temporary excavation support system that is compatible with subsurface conditions will be designed in order to provide adequate support and protection of the adjacent streets and utilities. It is anticipated that in general, the excavation support systems will consist of soldier piles and lagging or interlocking steel sheets.

2.4.8.4 Groundwater Conditions

Groundwater level measurements obtained at monitoring wells installed on and in the vicinity of the Project have been reviewed to develop an understanding of groundwater conditions and considerations for below-grade construction design and planning.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

Groundwater levels vary with season and other local influences, and groundwater levels ranging between 3 and 8 ft below grade (El. 9 to 14) were recorded in the past.

The proposed structure includes one below grade level. The foundation elements that are required to extend down to competent soils, below the groundwater level, will be solid, discontinuous, discrete elements that will not cause the groundwater to raise, pond or be lowered.

The Project is located within the Groundwater Conservation Overlay District (GCOD). The Project design will comply with GCOD and City standards by establishing design and construction methodology which protects groundwater. The Project will demonstrate that the permanent construction results in no negative impacts to groundwater levels through engineering evaluations. An engineers' certification report will be submitted to demonstrate that the standards have been met. Methods to assure these standards include use of fully waterproofed basement (walls and lowest level floor slabs) for the portion of the structure that extends below groundwater levels which will be designed to resist hydrostatic uplift pressures. Design criteria for the Project will include provision that no long term groundwater pumping will be allowed.

Roof runoff from the Project will be directed to an underground infiltration system at the rear of the proposed building. The infiltration system will likely consist of plastic chambers surrounded by crushed stone and wrapped in geotextile. The system has been sized to retain and infiltrate a volume of stormwater greater than 1" of rainfall over the entire roof area. Supporting design calculations are noted on the schematic site plan. See Figure 2-11 under Infrastructure Systems.

The Proponent has met with the Boson Groundwater Trust (BGwT) to review the proposed infiltration system as well as groundwater monitoring prior to and during construction. BGwT has confirmed that the proposed infiltration system location is acceptable. One groundwater monitoring well will be installed prior to construction to document existing groundwater levels and hydrogeologic conditions. The well will be installed in accordance with City and BGwT standards for permanent monitoring wells. The proposed well location is in the vicinity of the Chief Medical Examiner's Office building where it will be accessible for long term monitoring.

2.4.9 Water Quality

The proposed Project will be designed and constructed to protect surface and ground waters from negative impact to water quality both during and post construction. The site of the proposed Project is currently 100% paved and used for parking and as a storage area. Approximately 11,000 s.f. of this pavement area will be removed and replaced with a new building. Runoff from the new building roof, which is not subjected to parking lot pollutants such as sand and salt, will likely be free of sediments and will be able to be infiltrated into the ground. Runoff from the proposed building will be directed to a new infiltration system at the rear of the project site. The replacement of paved parking area with building area will

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

decrease the pollutant load in runoff from the site and help to improve water quality within the area.

Stormwater runoff from the site during construction will be monitored and is expected to be minimal. It will be controlled through the use of sedimentation barriers, catch basin silt sacks, stabilized construction entrances and other appropriate Best Management Practices (BMP's). These BMP's will serve to protect water quality by preventing sediment laden runoff from leaving the work area and entering the existing stormwater system and ultimately Boston Harbor.

2.4.10 Solid and Hazardous Wastes

2.4.10.1 Existing Soil Conditions

Testing of soil and groundwater is planned in advance of construction to characterize materials to be excavated; to support planning for off-site disposition of soils and management of construction dewatering effluent; and to identify environmental regulatory requirements, if applicable.

2.4.10.2 Construction Waste and Disposal

Solid waste generated by construction will consist of excavated material and debris. Excavated material will be composed of miscellaneous fill and underlying natural deposits. Excavation and off-site disposition will be conducted in accordance with a Soil Management Plan developed for the Project and included as part of the Construction Documents. The Soil Management Plan will describe procedures for identification, management and off-site transport of any contaminated soils. Management of soil during excavation and construction will be conducted in accordance with applicable local, state, and federal laws and regulations.

Construction dewatering will be conducted in accordance with a Groundwater Management Plan that will be included as part of the Construction Documents. The Groundwater Management Plan will describe the procedures for maintenance of groundwater levels and for the treatment (if necessary) and discharge of effluent from dewatering activities.

2.4.10.3 Solid Waste Generation and Recycling

The Project will generate solid waste from employee and staff maintenance offices such as wastepaper, cardboard, glass bottles, aluminum cans, etc. Recycling of this material will be encouraged and managed through Boston University Medical Center's active campus recycling program. There are staging areas in the existing Power Plant for recycling bins that will accommodate the recyclable material from the Energy Facility.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

2.4.11 Rodent Control

A rodent extermination certificate will be filed with the building permit application to the City. Rodent inspection monitoring and treatment will be carried out before, during, and at the completion of all construction work for the proposed Project, in compliance with the City's requirements. Rodent extermination prior to work start-up will consist of treatment of areas throughout the site. During the construction process, regular service visits will be made.

2.4.12 Wildlife Habitat

The site is within a fully developed urban area and, as such, the proposed Project will not impact wildlife habitats as shown on the National Heritage and Endangered Species Priority Habitats of Rare Species and Estimated Habitats of Rare Wildlife.

2.5 Construction Management Plan

A Construction Management Plan (CMP) will be submitted to the Boston Transportation Department (BTD) for review and approval prior to issuance of a building permit. The CMP will define truck routes which will help minimize the impact of trucks on local streets. The construction contractor will be required to comply with the details and conditions of the approved CMP.

Construction methodologies that ensure public safety and protect nearby businesses will be employed. Techniques such as barricades, walkways, painted lines, and signage will be used as necessary. Construction management and scheduling, including plans for construction worker commuting and parking, routing plans and scheduling for trucking and deliveries, protection of existing utilities, maintenance of fire access, and control of noise and dust, will minimize impacts on the surrounding environment.

2.5.1 Construction Schedule and Coordination

Construction of the Project is estimated to last approximately 18 months. Initial site work is expected to begin during the 4th Quarter of 2010.

Typical construction hours will be from 7:00 am to 6:00 pm, Monday through Friday, with most shifts ordinarily ending at 3:30 pm. No sound-generating activity will occur before 7:00 am. If longer hours, additional shifts, or Saturday work is required, the Construction Manager will place a work permit request to the Boston Air Pollution Control Commission and BTD in advance. Notification should occur during normal business hours, Monday through Friday. It is noted that some activities such as finishing activities could run beyond 6:00 pm to ensure the structural integrity of the finished product. (Certain components must be completed in a single pour and placement of concrete cannot be interrupted.)

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

Proper planning with the City, neighborhood and developers of other projects under construction in the area will be essential to the successful construction of the Project. The construction contractor will be responsible for coordinating construction activities during all phases of construction with City of Boston agencies to minimize potential scheduling and construction conflicts with other ongoing construction projects in the area.

2.5.2 Construction Staging and Public Safety

Primary staging will be on-site. The proposed construction staging plan will be designed to isolate the construction while providing safe access for pedestrians and vehicles during normal day-to-day activities and emergencies. The staging areas will be secured by chain-link fencing to protect pedestrians from entering these areas.

Although specific construction and staging details have not been finalized, the Proponent and its construction management consultants will work to ensure that staging areas will be located to minimize impacts to pedestrian and vehicular flow. Secure fencing and barricades will be used to isolate construction areas from pedestrian traffic adjacent to the site. In addition, sidewalk areas and walkways near construction activities will be well marked and lighted to protect pedestrians and ensure their safety. If required by BTB and the Boston Police Department, police details will be provided to facilitate traffic flow. Construction procedures will be designed to meet all Occupational Safety and Health Administration (OSHA) safety standards for specific site construction activities.

2.5.3 Construction Employment and Worker Transportation

The number of workers required during the construction period will vary, with an estimated average daily work force ranging from approximately 10 to 20. The Proponent will make reasonable good-faith efforts to have at least 50 percent of the total employee work hours for Boston residents, at least 25 percent of total employee work hours for minorities and at least 10 percent of the total employee work hours for women. The Proponent will enter into a construction jobs agreement with the City of Boston.

To reduce vehicle trips to and from the construction site, minimal construction worker parking will be available at the site and all workers will be strongly encouraged to use public transportation and ridesharing options. The Proponent and contractor will work aggressively to ensure that construction workers are well informed of the public transportation options serving the area. Five bus routes currently service the area, and the Project site is proximate to the Silver Line. Space on-site will be made available for workers' supplies and tools so they do not have to be brought to the site each day.

2.5.4 Construction Truck Routes and Deliveries

The construction team will manage deliveries to the site during morning and afternoon peak hours in a manner that minimizes disruption to traffic flow on adjacent streets. The construction team will provide subcontractors and vendors with Construction Vehicle &

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

Delivery Truck Route Brochures in advance of construction activity. “No Idling” signs will be included at the loading, delivery, pick-up and drop-off areas.

Truck traffic will vary throughout the construction period depending on the activity. Construction truck routes to and from the Project site for contractor personnel, supplies, materials, and removal of excavations will be coordinated by the Proponent with the BTD and established in the CMP. These routes will be mandated as a part of subcontractors’ contracts for the Project. Traffic logistics and routing are planned to minimize community impacts.

See also Section 2.3.4 for more information.

2.5.5 Construction Noise

The Proponent is committed to mitigating noise impacts from Project construction. Construction work will comply with the requirements of the City of Boston Code -- Ordinances and the Regulations for Control of Noise in Boston administered by the Boston Environment Department. Every reasonable effort will be made to minimize the noise impact of construction activities.

Construction period noise mitigation measures are expected to include the following:

- Instituting a proactive program to ensure compliance with the City of Boston ordinances and regulations;
- Using appropriate mufflers on all equipment and ongoing maintenance of intake and exhaust mufflers;
- Muffling enclosures on continuously running equipment, such as air compressors and welding generators;
- Replacing specific construction operations and techniques by less noisy ones where feasible;
- Scheduling equipment operations to keep average noise levels low, to synchronize noisiest operations with times of highest ambient levels, and to maintain relatively uniform noise levels;
- Turning off idling equipment; and
- Locating noisy equipment at locations that protect sensitive locations by shielding or distance.

2.5.6 Construction Air Quality

Impacts associated with construction activities may generate fugitive dust, which will result in localized increases in airborne particulate levels. Fugitive dust emissions from construction activities will depend on such factors as the properties of the emitting surfaces (e.g., moisture content, and volume of spoils), meteorological variables, and construction practices employed.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

To reduce emissions of fugitive dust and minimize impacts on the local environment, the construction work will adhere to a number of strictly enforced mitigation measures. These measures may include the following:

- Using wetting agents regularly to control and suppress dust that may come from the construction materials;
- Fully covering all trucks used for transportation of construction debris;
- Retrofitted equipment and ultra low-sulfur diesel (ULSD) fuel (15 ppm) will be used, in off-road construction equipment;
- Removing construction debris from each site regularly as needed;
- Monitoring construction practices to ensure that unnecessary transfers and mechanical disturbances of loose materials are minimized and to ensure that any emissions of dust are negligible;
- Providing a wheel wash at all exits from the construction areas; and
- Regular vacuum cleaning of streets and sidewalks in the Project area will be employed to ensure that they remain free of dust and debris from the Project.

2.5.7 Construction Waste

The Proponent will reuse or recycle construction materials to the extent feasible. Construction procedures will allow for the segregation, reuse, and recycling of materials. Materials that cannot be reused or recycled will be transported in covered trucks by a contract hauler to a licensed facility, per the MassDEP regulations for Solid Waste Facilities, 310 CMR 16.00.

2.5.8 Protection of Utilities

Existing public and private infrastructure located within the public right-of-way will be protected during construction. The installation of proposed utilities within the public way will be in accordance with the BWSC, Boston Public Works Department, the Dig Safe program, and the governing utility company requirements. All necessary permits will be obtained before the commencement of the specific utility installation. Specific methods for constructing proposed utilities where they are near to, or connect with, existing water, sewer and drain facilities will be reviewed by BWSC as part of its Site Plan Review Process.

2.6 Historic and Archaeological Resources

2.6.1 Historic Resources

Boston University Medical Center is located within the South End Protection Area, formed to maintain an architecturally compatible boundary adjacent to the south border of the South End National Register and Landmark Districts.

The proposed Energy Facility site is located adjacent to the existing Power Plant at 750 Albany Street on the BUMC Campus, just north of the Massachusetts Avenue Connector

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

and west of East Concord Street. See Figures 1-1 through 1-3 for Project location and campus map.

The Project Site is located within the South End Harrison/Albany Protection Area (“Protection Area”) and is subject to review by the South End Landmarks District Commission (“SELDC”). According to the Standards and Criteria of the SELDC, the following activities are subject to review: demolition, land coverage, height of structure, topography, and landscaping. The goals of the Protection Area are to protect views of the adjacent Landmark District and to insure that new development is architecturally compatible in massing, setback and height to protect light and air circulation within the Landmark District.

The height limit for the area southeast of Albany Street is 150 feet. The Project has a height of 100 feet from grade to the top of the partially enclosed penthouse and complies with the standard. The height of the proposed stacks is 160 feet which is dictated by the requirements to meet the EPA National Ambient Air Quality Standards (NAAQS). The height of the new stacks is considered an addition to the structure and may exceed the allowed height of 150 feet if not visible from the nearest public way within the Landmark District.

The Project team has performed a view analysis and determined that the additional height is not visible from the nearest public way within the Landmark District. The Proponent presented the Project to the SELDC at its March 4, 2010 hearing. The SELDC confirmed that the height of the stacks is not visible from the nearest public way within the Landmark District and voted to approve the Project as presented. If review by the MHC is required, the appropriate project documentation will be submitted. Due to the small scale of the proposed Project, no adverse effects to State Register properties are anticipated.

2.6.2 Archaeological Resources

A review of the National Register and Inventory of Historic and Archaeological Assets of the Commonwealth identified no previously known archaeological resources within the Project site.

2.7 Infrastructure Systems

2.7.1 Introduction

This section evaluates the infrastructure systems that will support the proposed Energy Facility. Based on initial investigations and consultations with the regulating agencies and utility companies, the existing infrastructure systems in the area appear to be able to accommodate the incremental increase in demand associated with the proposed Project.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

The design process for the proposed Energy Facility will include the required engineering analyses and will adhere to applicable protocols and design standards, ensuring that the proposed Project is properly supported by and properly uses the City's infrastructure.

The systems discussed below include those owned or managed by the Boston Water and Sewer Commission (BWSC), private utility companies, and on-site infrastructure. There will be close coordination between these entities and the Project team during subsequent reviews and the design process. All improvements and connections to BWSC infrastructure will be reviewed as part of the BWSC site plan review process. This process includes a comprehensive design review of the proposed service connections, assessment of system demands and capacity and establishment of service accounts. See Figure 2-11 – Schematic Site Plan, for proposed utility connections.

2.7.2 Regulatory Framework

All connections will be designed and constructed in accordance with city, state and federal standards.

- In the City of Boston, BWSC is responsible for all water, sewer and stormwater systems.
- The Boston Fire Department (BFD) will review the proposed Project with respect to fire protection measures such as Siamese connections and standpipes.
- Design of the site access, hydrant locations, and energy systems (gas, steam and electric) will also be coordinated with the respective system owners.
- New utility connections will be authorized by the Boston Public Works Department through the street opening permit process, as required.
- New Steam and Power conduits between campus buildings and within City Streets will require permitting with the Public Improvements Commission.

2.7.3 Wastewater

2.7.3.1 Existing Wastewater

Local sewer service in the City of Boston is provided by the BWSC. Wastewater generated in the proposed Project area will be conveyed to the Massachusetts Water Resources Authority (MWRA) facility on Deer Island via the 66" x 68" interceptor on Albany Street.

2.7.3.2 Demand/Use

The proposed Project will generate approximately an average of 22 gallons per minute or 31,800 gallons per day of wastewater from the proposed building. This wastewater will be mostly generated from process water during the steam generation and condensate. It is estimated that the peak wastewater generation from the proposed building will be approximately 85 gallons per minute. These flow rates were reviewed with BWSC and determined that the existing sewer has capacity to handle these flows.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

2.7.3.3 Proposed Connection

As shown on the schematic site plan, the wastewater generated by the Project will be piped by a new sanitary service to the existing sewer in Albany Street. The Proponent will coordinate with the BWSC on the design and capacity of the proposed connection to the sewer system. In addition, the proponent will submit a General Service Application and site plan for review as the proposed Project progresses.

2.7.4 Domestic Water and Fire Protection

2.7.4.1 Existing Water Supply System

The proposed Project is located in the South End service area of the BWSC public water supply service areas. Albany Street is served by 12-inch high and low pressure lines. Domestic water demand will be determined by the rate of steam production. It is estimated that the proposed Project will require approximately an average of 432,000 gallons of water per day with a peak demand of 600 gallons per minute.

Hydrant test data provided by the BWSC is presented in Table 2-11 below.

Table 2-11 Hydrant Test Data

Date	Location	Static Pressure (psi)	Residual Pressure (psi)	Total Flow (gpm)	Flow (gpm) at 20 psi ¹
3/21/05	12" Low Albany Street	68	62	3,182	1,083
9/26/00	12" High Albany Street	96	88	4,388	1,479

¹ psi = pounds per square inch

The results of the hydrant flow test indicate the actual amount of water (flow) available and the actual pressure (residual) flow provided. These flow metrics are analyzed to establish the quantity of water that will be delivered at 20 psi as a common evaluation point.

2.7.4.2 Proposed Connection

Domestic water service for the project will be provided from the existing 12" low pressure water main on the north side Albany Street as shown on the site plan. The project proposes two separate domestic lines to provide redundant service for the purpose of periodic maintenance shutdown or disruption to one of the service lines.

As shown on the schematic site plan, a fire service will be provided for the building sprinkler system. This service will be connected to the existing 12" high pressure main on the south side of Albany Street.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

The Project flow rates were reviewed with BWSC. BWSC indicated that the proposed connections will be acceptable and the existing mains have capacity to handle these flows. Compliance with the standards for the domestic water system service connections will continue to be reviewed as part of BWSC's Site Plan Review Process. The review includes but is not limited to sizing of water supply and fire protection services, calculation of meter sizing, backflow prevention design, and location of hydrants and Siamese connections to conform to BWSC and Boston Fire Department requirements.

2.7.5 Stormwater Management

2.7.5.1 Existing Conditions

The BUMC Campus is serviced by several BWSC drain lines. The Project site is occupied entirely by paved parking and driveways. Runoff from the site flows southerly and is captured by the existing catch basin immediately adjacent to the proposed building and the west wall of the Chief Medical Examiner's office building. The catch basin is piped southerly and connects drains behind the Chief Medical Examiner's office building which connects directly to the Roxbury Canal Conduit.

2.7.5.2 Proposed Conditions

Stormwater from the site will be routed to follow existing infrastructure to the Roxbury Canal Conduit. As per Section 2.4.8.3 – Groundwater Conditions, the project will be required to infiltrate 1" of runoff per square foot of new building footprint. Additional run-off from non-roof areas and storms in excess of 1" of rainfall will discharge to the Roxbury Canal Conduit. Because the Project site is entirely an existing paved surface, the proposed Project will not change the overall area of impervious surface and will not result in an increase in stormwater generation from the site. The introduction of a stormwater infiltration system will result in a net decrease in the amount of stormwater discharged from the site and increase the recharge to the aquifer. There will be no change in the drainage patterns or increase to any portion of the BWSC drainage system.

The schematic site plan was reviewed with BWSC. Because there is no increase in impervious area and there will be a net decrease in runoff with the introduction of the infiltration system, it has been determined that a detailed drainage analysis will not be required.

Stormwater management controls will be established in compliance with BWSC standards and the Groundwater Conservation Overlay District. The proposed Project will be designed so as to not introduce increased peak flows, pollutants, or sediments to existing drainage infrastructure. In conjunction with the site plan and the General Service Application, the proponent will submit a stormwater management plan to the BWSC. Compliance with the standards for the final site design will be reviewed as part of the BWSC Site Plan Review Process.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

2.7.6 Anticipated Energy Needs

2.7.6.1 Natural Gas Service

Natural gas for the Project will be provided by National Grid. The building will tie into the existing 30" gas main in Albany Street.

2.7.6.2 Electrical Service

Boston University Medical Center purchases electricity from NSTAR Electric in bulk and redistributes from the existing Power Plant located immediately adjacent to the proposed Project site. New electric services will be constructed on campus to distribute power generated by the Project. The Energy Facility will cogenerate electrical power and heat (steam) and is anticipated to generate an average of 314,200 kWh per day. See Section 2.2.2 for more information.

2.7.6.3 Steam

The proposed Project is a new combined heat and power generating facility. Steam and electric energy generated by the proposed Project will be distributed to the BUMC Campus and BioSquare buildings through existing and new infrastructure.


The Project is anticipated to generate on average 4,124,000 lbs of steam per day. This steam is sufficient to supply Boston University Medical Center's needs and will negate the need for importing steam from offsite sources.

2.7.6.4 Telecommunications

Verizon will provide telephone and telecommunication services to the proposed Project. The Project will receive telecommunication service directly from the existing Power Plant.

2.0 ASSESSMENT OF DEVELOPMENT REVIEW COMPONENTS

Figure 2-11 Schematic Site plan



Section 3.0

3.0 COORDINATION WITH OTHER GOVERNMENTAL AGENCIES

3.1 Introduction

BMC has initiated consultation with other governmental agencies as required by the Project and will continue outreach as necessary.

3.1.1 Architectural Access Board Requirements

At this time, there are no modifications to the public realm as part of the Project. Sidewalk improvements will occur as part of the previously approved Shapiro Ambulatory Care Center (“SACC”) in front of the Power Plant along Albany Street. Modifications to the public realm that occur as a result of the Project will comply with requirements of the Massachusetts Architectural Access Board, and will be designed to comply with the standards of the Americans with Disabilities Act.

3.1.2 Massachusetts Environmental Policy Act

The Proponent will consult with the office of the Massachusetts Environmental Policy Act (MEPA) for advisement on requirements for project review subsequent to filing of this DPIR.

3.1.3 Massachusetts Historical Commission / South End Landmark District Commission

The proposed Energy Facility Project will require a state permit and will require review by the Massachusetts Historical Commission (“MHC”) because it is located within the South End Harrison/Albany Protection Area adjacent to the South End Landmark District. BMC will file the appropriate project documentation with MHC in compliance with MHC requirements. Pursuant to the regulations and procedures of MHC, BMC will enter into discussions with MHC relative to impacts of the proposed Project on the state register properties, if necessary.

The proposed Energy Facility is located within the South End Harrison/Albany Protection Area of the South End (“Protection Area”). Activities relating to demolition, land coverage, height of structure, topography and landscaping are subject to review by the South End Landmarks District Commission (“SELDC”). The Proponent presented the Project to the SELDC at its March 4, 2010 hearing and the SELDC voted to approve the Project as presented.

3.1.4 Boston Civic Design Commission

The Proponent met with BCDC staff to review the Project. The Proponent will coordinate with BCDC staff to submit design and development related materials as necessary for final approval.

3.0 COORDINATION WITH OTHER GOVERNMENTAL AGENCIES

3.1.5 Other Permits and Approvals

Section 1.7 includes a list of anticipated permits and approvals required for the Proposed Project.

Section 4.0

4.0 RESPONSE TO COMMENTS

Four comment letters were submitted by City of Boston public agencies on the PNF during the comment period. This section addresses the individual comments within each comment letter. Each comment within each letter is numbered and responses are provided below. As required by the BRA Scoping Determination dated 11/16/09, the following is the full response to such comments. The Scoping Determination and copy of each comment letter is included in Appendix E.

Table 4.1 Comment Letters on the PNF

Commenters	Abbreviation
<i>City Agencies</i>	
Boston Public Works Department	PWD
Boston Environment Department	BED
Boston Groundwater Trust	BGwT
Boston Water & Sewer Commission	BWSC

Boston Public Works Department

PWD.1 Site Plan

The Proponent has included a Schematic Site Plan in the DPIR that shows existing conditions, curb functionality, and the proposed Project. See Figure 2-11.

PWD.2 Sidewalks

The Proponent will reconstruct the sidewalk along Albany Street in front of the Power Plant site as part of the previous PIC approvals for the Shapiro Ambulatory Care Center (SACC). Other improvements include new street trees and grates, new street lights, etc. See Section 2.1.7 for further discussion as well as Figure 1-4 which is the rendered site plan.

PWD.3 Pedestrian Accessibility

As noted above, the sidewalks in front of the Power Plant along Albany Street will be reconstructed as part of the previous PIC approvals for the SACC. These improvements will meet PWD requirements and will be in full compliance with ADA/AAB.

PWD.4 Discontinuances

No discontinuances are required for the project as currently designed.

4.0 RESPONSE TO COMMENTS

PWD.5 Landscaping

The landscape elements that will occur as part of the SACC approvals within the public sidewalk of Albany Street have been approved by the Boston Parks and Recreation Commission and the Proponent has executed an LM&I with the PIC. The Proponent will work with Mr. Crasco and the PIC should any changes occur to the previously approved landscape elements as a result of the Project. See Section 2.1.7 and Figure 1-4.

PWD.6 Street Lighting

New street lighting will be installed along Albany Street in front of the Power Plant site as part of the SACC approvals. The Proponent will work with Mr. Banks in connection with any changes that may occur as a result of the Energy Facility Project. See Section 2.1.7 and Figure 1-4.

PWD.7 Roadway

The Proponent acknowledges that if construction of the proposed Project necessitates any street reconstruction, such reconstruction is the responsibility of the Proponent.

PWD.8 Roadway Clearance

The Proponent has been in contact with Mr. Cardarelli. The design team is currently working with the City Engineer, Mr. Linsky, to coordinate the schedule for the Energy Facility and the City's Asphalt Resurfacing Program on Albany Street. Mr. Cardarelli has confirmed that the design team can proceed with BWSC site plan review and the design team will meet with Mr. Linsky during this process.

PWD.9 Public Trash Receptacles

The Proponent will consult with Mr. McCarthy to determine whether any solar powered trash compactors are required.

PWD.10 Public Art

The Proponent will contact Ms. Goodfellow.

PWD.11 Groundwater

The Proponent has met with Mr. Laffer of the Boston Groundwater Trust. The Proponent has committed to installing one groundwater monitoring well in the vicinity of the Chief Medical Examiner's Office building along Albany Street. This location is determined to be suitable to Mr. Laffer. The Proponent will convey the wells to the Groundwater Trust upon completion of the Project through the PIC. See Section

4.0 RESPONSE TO COMMENTS

2.4.8.4.

Boston Environment Department

BED.1 LEED Credits

As demonstrated by the efforts of Boston University Medical Center's sustainable initiatives discussed in Section 1.3, the Proponent is committed to sustainable design and operations. This commitment is reinforced with the development of the Energy Facility. Please see Section 2.2 for a detailed discussion on broader environmental goals of the Project and additional sustainable design measures being considered for the Project. A preliminary LEED checklist is included in Appendix C.

BED.2 Green Roof

A green roof is not feasible due to requirements for rooftop mechanical equipment. However, the Proponent is considering a high emissivity roof material such as white TPO.

BED.3 Elevators

The Project design and occupant load does not require an elevator.

BED.4 Plaques for Catch Basins & Drains

The Proponent will install permanent castings stating "Don't Dump: Drains to Boston Harbor" next to any catch basin or drains that exist, are created or modified as part of the Project.

BED.5 Shadow Diagrams

Shadow diagrams provided in the PNF did include the emissions stacks. Due to the slender nature, location and position of these elements, shadow impacts are almost imperceptible. Please see Section 2.4.3 and Appendix B for the shadow analysis.

BED.6 Construction Noise and Air Quality

The Proponent will ensure compliance with City of Boston noise regulations and manage air quality during construction. Please see Sections 2.5.5 and 2.5.6 for a more detailed discussion.

BED.7 Bicycles and Shower Facilities

Boston University Medical Center has a very active bicycle program. Please see Section 2.3.3. The Proponent anticipates installing new lockable bicycle racks for employees and staff of the Energy Facility adjacent to the building where feasible.

4.0 RESPONSE TO COMMENTS

The existing staff locker room in the Power Plant is equipped with a shower for use by employees and staff of that department. It will accommodate the 7 new employees and staff of the Energy Facility.

BED.8 Clean Air Construction Initiative

The Proponent will participate in the Clean Air Construction Initiative.

BED.9 Stack Height

The height of the stacks slightly exceeds the 150 foot limitation, but the height is considered an addition to the structure and is not visible from the nearest public way within the Landmark District. The Project meets the Specific Standards and Criteria for the South End Harrison/Albany Protection Area. The Proponent presented the Project to the SELDC at its March 4, 2010 hearing and the SELDC voted to approve the Project as presented. Please see Section 2.6 for a detailed discussion. The height of the stacks is dictated by the requirement to meet the EPA's National Ambient Air Quality Standards (NAAQS) in accordance with the Clean Air Act. See Section 2.4.5 for a detailed discussion regarding Air Quality.

Boston Groundwater Trust

BGwT.1 Recharge System

The Proponent met with Mr. Laffer of the Boston Groundwater Trust to review the locations and design of the proposed recharge system. Mr. Laffer has determined that the proposed plan is acceptable. A description of the recharge design is included in Section 2.4.8.4 and 2.7.5.2 and shown on Figure 2-11.

BGwT.2 Groundwater Monitoring Well

The Proponent will install a monitoring well in the vicinity of the Chief Medical Examiner's Office building along Albany Street. This location has been accepted by Mr. Laffer. See Section 2.4.8.4. The Proponent will share data from the monitoring well with the Trust during construction and will turn the readings over to the Trust after construction.

BGwT.3 Compliance with Article 32

The site is located within the Groundwater Conservation Overlay District. The Project will not result in negative impact to groundwater. As noted in BGwT.1, the Proponent will install a recharge system that will meet the groundwater standards. Please see Section 2.4.8.4 for a detailed discussion and Figure 2-11.

4.0 RESPONSE TO COMMENTS

Boston Water & Sewer Commission

BWSC.1 Site Plan and General Service Application Review

The Proponent will submit to the Commission the required plans, details and supplemental documents as required through the Boston Water and Sewer Commission's Site Plan Review process.

BWSC.2 Capacity of Water, Sewer, and Storm Drainage Systems

The DPIR provides an evaluation of water, sewer and storm drainage systems. The Proponent will update the analysis of the proposed Project's impacts on these systems as part of the Site Plan Review process.

BWSC.3 Water Demand, Wastewater Generation, and Stormwater Runoff

The Proponent will provide the requested estimates and quantities as part of the Site Plan Review process.

BWSC.4 New or expanded water mains, sewers and storm drains

The Proponent will submit to the Commission the required plans, details and supplemental documents as required through the Boston Water and Sewer Commission's Site Plan Review process and General Services Application.

BWSC.5 Project Design 50 Percent Complete

The Project's civil engineer met with BWSC to review the Project's preliminary design. The Proponent will continue to meet with BWSC as the design progresses to ensure compliance with the Commission's requirements.

BWSC.6 Separate sanitary sewer and storm drains

Separate sanitary sewer and storm drain services will be provided for the Proposed Project.

BWSC.7 Drainage from building roofs and impervious areas

The Site Plan for the Proposed Project will show the roof drains and site drains and their destinations. See Section 2.7.5 for a detailed discussion regarding the stormwater management and recharge design and Figure 2-11 for the Schematic Site Plan.

BWSC.8 DEP Infiltration/Inflow Reduction

The Proponent will work with BWSC to identify improvements and an inflow

4.0 RESPONSE TO COMMENTS

reduction plan.

BWSC.9 Stormwater Discharge

Please see Section 2.7.5 for detailed discussion on stormwater management.

BWSC.10 Construction Dewatering Discharge

The Proponent will obtain all required discharge permits.

BWSC.11 Stormwater Pollution Prevention Plan

The Proponent will develop and submit a Stormwater Pollution Prevention Plan which will comply with the Commission's requirements.

BWSC.12 Installations of Meter Transmitting Unit (MTU)

The Proponent will coordinate with the Commission's Meter Installation Department regarding the installation and connection of the MTU.

BWSC.13 Water Conservation

The Proponent is not proposing outdoor landscaping at this time. The Project is located in the Groundwater Conservation Overlay District. Stormwater captured in the recharge system will be used to recharge the groundwater. The Proponent is considering the use of sensor operated faucets and low flow fixtures for sinks and toilets.

Appendix A



Photo 1: Aerial View looking south toward Dorchester.
Albany St in the foreground with north facade of existing power plant (center).





Photo 2: Aerial View looking north toward South End.
Intersection of Massachusetts Ave and Meinea Cass Blvd in foreground. South facade of existing power plant and medflight helipad (right).




CONTEXT PHOTOGRAPHS



Photo 1: View from BMC parking garage looking south.
Existing medflight helipad, chief medical examiner parking foreground, Mass Ave connector beyond.



Photo 2: View from BMC parking garage looking southwest.
East facade of existing power plant, chief medical examiner roof in foreground, Finland building beyond.




CONTEXT PHOTOGRAPHS



Photo 3: View from existing heliport looking north. South facade of existing power plant.



Photo 4: View from Albany Street looking south. East facade of existing power plant.



CONTEXT PHOTOGRAPHS


September 25, 2009




Photo 5: View from SACC looking east.
North facade of existing power plant (right), west facade of chief medical examiner building (left).





Photo 6: View from helpad access road looking northeast.
Levels 1 and 2 of existing power plant, west facade of chief medical examiner building




Appendix B














(I:\04022010\05_1006_110667_PlanetAlbany\Communications\Presentations\002\11067_PlanetAlbany_02051011067.dwg)
























Appendix C



LEED 2009 for New Construction and Major Renovation

Project Checklist

BMC - New Energy Facility

17-Feb

18 | 7 | 1 | Sustainable Sites | Possible Points: 26

Y	N	?	Prereq	Description	Points
1			Credit 1	Construction Activity Pollution Prevention	1
5			Credit 2	Site Selection	5
1			Credit 3	Development Density and Community Connectivity	1
6			Credit 4.1	Brownfield Redevelopment	6
1			Credit 4.2	Alternative Transportation—Public Transportation Access	1
3			Credit 4.3	Alternative Transportation—Bicycle Storage and Changing Rooms	3
2			Credit 4.4	Alternative Transportation—Low-Emitting and Fuel-Efficient Vehicles	2
1			Credit 5.1	Alternative Transportation—Parking Capacity	1
1			Credit 5.2	Site Development—Protect or Restore Habitat	1
1			Credit 6.1	Site Development—Maximize Open Space	1
1			Credit 6.2	Stormwater Design—Quantity Control	1
1			Credit 7.1	Stormwater Design—Quality Control	1
1			Credit 7.2	Heat Island Effect—Non-roof	1
1			Credit 8	Heat Island Effect—Roof	1
1				Light Pollution Reduction	1

0 | 6 | 4 | Water Efficiency | Possible Points: 10

Y	N	?	Prereq	Description	Points
4			Credit 1	Water Use Reduction—20% Reduction	4
2			Credit 2	Water Efficient Landscaping	2
2			Credit 3	Innovative Wastewater Technologies	2
2				Water Use Reduction	2

2 | 31 | 2 | Energy and Atmosphere | Possible Points: 35

Y	N	?	Prereq	Description	Points
17			Credit 1	Fundamental Commissioning of Building Energy Systems	17
2			Credit 2	Minimum Energy Performance	2
2			Credit 3	Fundamental Refrigerant Management	2
2			Credit 4	Optimize Energy Performance	2
3			Credit 5	On-Site Renewable Energy	3
2			Credit 6	Enhanced Commissioning	2
2				Enhanced Refrigerant Management	2
2				Measurement and Verification	2
2				Green Power	2

4 | 9 | 1 | Materials and Resources | Possible Points: 14

Y	N	?	Prereq	Description	Points
3			Credit 1.1	Storage and Collection of Recyclables	3
1			Credit 1.2	Building Reuse—Maintain Existing Walls, Floors, and Roof	1
2			Credit 2	Building Reuse—Maintain 50% of Interior Non-Structural Elements	2
2			Credit 3	Construction Waste Management	2
2				Materials Reuse	2

Materials and Resources, Continued

Y	N	?	Prereq	Description	Points
2			Credit 4	Recycled Content	2
1			Credit 5	Regional Materials	1
1			Credit 6	Rapidly Renewable Materials	1
1			Credit 7	Certified Wood	1

14 | 0 | 1 | Indoor Environmental Quality | Possible Points: 15

Y	N	?	Prereq	Description	Points
1			Prereq 1	Minimum Indoor Air Quality Performance	1
1			Prereq 2	Environmental Tobacco Smoke (ETS) Control	1
1			Credit 1	Outdoor Air Delivery Monitoring	1
1			Credit 2	Increased Ventilation	1
1			Credit 3.1	Construction IAQ Management Plan—During Construction	1
1			Credit 3.2	Construction IAQ Management Plan—Before Occupancy	1
1			Credit 4.1	Low-Emitting Materials—Adhesives and Sealants	1
1			Credit 4.2	Low-Emitting Materials—Paints and Coatings	1
1			Credit 4.3	Low-Emitting Materials—Flooring Systems	1
1			Credit 4.4	Low-Emitting Materials—Composite Wood and Agrifiber Products	1
1			Credit 5	Indoor Chemical and Pollutant Source Control	1
1			Credit 6.1	Controllability of Systems—Lighting	1
1			Credit 6.2	Controllability of Systems—Thermal Comfort	1
1			Credit 7.1	Thermal Comfort—Design	1
1			Credit 7.2	Thermal Comfort—Verification	1
1			Credit 8.1	Daylight and Views—Daylight	1
1			Credit 8.2	Daylight and Views—Views	1

5 | 1 | 0 | Innovation and Design Process | Possible Points: 6

Y	N	?	Prereq	Description	Points
1			Credit 1.1	Innovation in Design: Article 37 "Modern Grid" CHP System	1
1			Credit 1.2	Innovation in Design: Article 37 "Modern Mobility" TDM Plan	1
1			Credit 1.3	Innovation in Design: Green Cleaning Plan	1
1			Credit 1.4	Innovation in Design: Green Building Education Plan	1
1			Credit 1.5	Innovation in Design: Article 37 "Groundwater Recharge"	1
1			Credit 2	LEED Accredited Professional	1

2 | 2 | 0 | Regional Priority Credits | Possible Points: 4

Y	N	?	Prereq	Description	Points
1			Credit 1.1	Regional Priority: SSC6.1: Stormwater Design-Quantity Control	1
1			Credit 1.2	Regional Priority: SSC7.2: Heat Island Effect-Roof	1
1			Credit 1.3	Regional Priority: Specific Credit	1
1			Credit 1.4	Regional Priority: Specific Credit	1

45 | 56 | 9 | Total | Possible Points: 110

Certified 40 to 49 points Silver 50 to 59 points Gold 60 to 79 points Platinum 80 to 110

Appendix D

Green Committee Update

September 2009

New Construction

The Design and Construction department continues to evolve in utilizing green design and construction elements for our projects. Our most significant effort to date is the design and construction of the Shapiro Ambulatory Care Center currently beginning construction. The project is registered with Green Guide for Health Care (GGHC) which is based on the LEED point system (the original national model for sustainable building design). The GGHC system tracks all possible sustainable options utilized within a project. The Shapiro project is aspiring to gain points in optimizing energy performance, recycling and salvage non-hazardous construction and demolition debris, using low-emitting materials for interior paints and flooring systems, striving for occupant thermal comfort to name a few of the many point goals available in the GGHC program.

This project is a true success story in the efforts made by many BMC project team members to create the first official "green" based building on our campus and will be a major contribution to our goal of Patient Satisfaction here at BMC. As we move forward with all our capital projects, we will be incorporating as many green elements as possible in each project for all aspects of planning and construction thus ever widening the circle of contribution to our patients and campus environment.

Green Cleaning

BMC has used Green Seal Certified Chemicals throughout the year. Microfiber mops are coming and the savings in terms of cost and water consumption are impressive. Using 575 beds cleaned per day here are the differences per month

	Mop and Bucket	Microfiber
Cost	\$690.	25.88
Water gallons used	767	28.75

Recycling January – August '09

	<u>Tons</u>	<u>Gallons</u>
Paper	98.34	
Cardboard	119.52	
Comingled	11.247	
Metal	.2	
Bulbs	1.355	
Solvents		176
Cooking Oil		1,910
Total	230.66	2,086

All of these materials were removed from our waste stream reducing the cost of hauling and disposing of them.

Food and Nutrition (Focus on the Environment)

Implemented a sustainable seafood policy which protects endangered fish species. This has impacted 7,470 pounds of Cod this year.

Implemented a policy to protect the humane treatment of farm animals. This has resulted in the purchase of cage free eggs which impacts 100,000 eggs at BMC annually.

Transitioned all styrofoam trays from our retail operations which has resulted in removing 20,000 styrofoam trays annually from our waste stream.

We have removed all of our metals, plastics and glass from our kitchen waste stream which has resulted in 5 tons of comingled material recycled.

We have marketed a Reusable Coffee Mug program in our retail operations which has saved 52,000 paper cups, sleeves and lids from being tossed into our waste stream.

We have replaced all of our grab n go Plastic containers with a container which is made from 100% annually renewable resources; this has impacted 19,000 containers this year.

We have removed all of our plastic based lids from our retail operations which remove 156,000 lids from our waste stream annually

We are purchasing our dairy from a vendor which has partnered with local New England farms.

We have replaced all of our catering plastic trays and plastic hinged containers with a cardboard based solution which in turn is recycled and removed from the waste stream.

We recycle 3,600 gallons of cooking oil annually which in turn is transitioned into a fuel solution for vehicles.

Transportation

Transportation Solutions for Commuters, Inc.

TranSComm encourages all forms of alternative transportation to decrease traffic congestion in our neighborhood, to improve air quality and to encourage “green” awareness.

Listed are some of the successful TranSComm programs of alternative transportation:

Carpooling and Hybrid car use:

- Carpool and Hybrid Preferential Parking Program began June 18, 2007

- Additional capacity (twice as many) was added October 6, 2008.
- GOOSE NETWORKS introduced an innovative concept of ridesharing via text and cell phones as part of a state grant.
- Discounted ZIPCAR (“wheels when you want them”) program continues to be successful
- ZIPCAR now has one HYBRID and one conventional car on campus. (both are well utilized!)

Cycling:

- TWO, SECURE BIKE CAGES are available on campus with active membership of 348 cyclists
- TranSComm organized their FOURTEENTH Annual Bike-To-Work/School Event entitled, “Kick Gas”
 - Online registration, free bike luncheon for registered cyclists
 - TranSComm wins award for “Most Cyclists” in our size category (again!)
 - TWO Bike Safety Check Ups donated by REI and EMS - 70 cyclists served

Walking:

- MEDICAL HISTORY WALKS: this summer/fall we had four guided walks with local historian, Alison Barnet
- FIRE UP YOUR FOOT POWER SUMMER PROGRAM
(BUMC commuters reported their “foot power” commutes: walking, cycling, jogging, rollerblading, etc.)
Of the 10 participating TMA (transportation management associations) teams, TranSComm placed FIRST!
Our 161 participants actively commuted a combined total of 29,399 miles and prevented 23,206 lbs of CO2 from being emitted into the regional atmosphere. And to make it sweeter, four medical center employees won a check for \$25.00 that was awarded weekly during the summer.
Congratulations to all 161 members of our community that chose an active commute last summer.

MBTA Participation:

- Semester Pass Program offered with 11% discount
- BMC offers a 30% discount to employees
- Payroll-deducted, pre-taxed employee pass program delivered with paychecks, downloaded onto Charlie cards each month
- Distribution of MBTA bus schedules, notices, information, etc. at transportation kiosks in all lobbies and front desks
- MBTA mini-events, contests, incentives

Green Awareness:

- FIRST Green Transportation Fair with BMC Green Committee hosted hybrid car owners for informational event
- TranSComm is active in BMC and BU’s Green Committees

Personalized Commutes Planned:

- TranSComm plans individual alternative commutes for all members of the medical center seeking assistance.

Memberships

- Association for Commuter Transportation (ACT) • ACT/Patriot Chapter • Mass Bike • **Walk** Boston • Mass Commute • Transit Works

Pharmaceutical Waste Management

Hazardous Pharmaceuticals collection expanded from Pharmacy to clinical areas throughout hospital. This effort included creating and assigning an online training program for nursing staff, locating and distributing collection buckets, creating labeling through pharmacy and Pyxis machines, and signage at each collection location.

Food Pantry

Reduce the use of plastic at the pantry by approximately 50%. In 2007 we used 2 cases of bags per week. We are now using 1-1/2 cases a week with an increase of 51% of the number of people served.

Appendix E

BOSTON REDEVELOPMENT AUTHORITY

SCOPING DETERMINATION

FOR

INSTITUTIONAL MASTER PLAN NOTIFICATION FORM/PROJECT

NOTIFICATION FORM

BOSTON UNIVERSITY MEDICAL CENTER/BOSTON MEDICAL CENTER

ENERGY FACILITY

PREAMBLE

Boston University Medical Center (“BUMC”) is comprised of Boston Medical Center (“BMC”) and Boston University Medical Campus (“BU Medical Campus”) which includes three of Boston University’s health science schools – the School of Medicine, Goldman School of Dental Medicine and the School of Public Health. The BUMC campus is located in Boston’s South End neighborhood and is comprised of approximately 20 acres including 28 BUMC campus-owned or controlled buildings, a helipad and development parcels. BMC and BU Medical Campus also leases spaces in 8 buildings located on and/or proximate to the campus. Total BUMC owned or controlled and leased space is approximately 3 million square feet of usable space.

As stated in Section 80D-1 of the Boston Zoning Code (“Code”), “the purpose of Institutional Master Plan Review is to provide for the well-planned development of Institutional Uses in order to enhance their public service and economic development role in the surrounding neighborhoods.” Under the Code, an Institutional Master Plan (“IMP”) has a dual purpose of meeting the needs of the institution and relating the campus to its context in a positive way. In preparing its IMP and Supplemental Materials, BUMC will need not only to demonstrate an understanding of its future facilities needs but also the context of its campus; identification of all owned, leased and planned space, land uses, physical characteristics, planned changes, resident desires, and applicable public policy.

The BRA also seeks to enhance BUMC's presence in the City of Boston as an important economic development entity and employer. Care should be taken to respond to the concerns outlined below:

1. The BRA seeks to understand the long-term plans of its institutions in the so that necessary growth by institutions can be allowed on a fair and equitable basis. Therefore, the BRA requires 10 year IMPs of all institutions. Institutions will be required to provide updates to the BRA on the status of their IMP and any projects and commitments therein every 2 years on the anniversary of their approval by the Boston Zoning Commission.
2. Attractive residential neighborhoods are viewed by the BRA as being vital to the long-term success of Boston. BUMC sits within the context of the South End neighborhood. Impacts from institutional project construction, operations and expansion must have minimal negative impacts on the neighborhoods and BUMC should take appropriate steps to ensure this.
3. A Task Force has been appointed to assist and advise the BRA on the BUMC IMP and Proposed Projects. BUMC is requested to provide 2 year regular updates to Task Force members in addition to the BRA.

SUBMISSION REQUIREMENTS

The Boston Redevelopment Authority (“BRA”) is issuing this Scoping Determination pursuant to Section 80D-1 and Section 80B-5 of the Boston Zoning Code (the “Code”). Pursuant to Article 80D of the Boston Zoning Code (“Code”) the Boston University Medical Center Corporation and the Trustees of Boston University (collectively known as the “Proponents”) submitted an Institutional Master Plan Notification Form (“IMPINF”) to the Boston Redevelopment Authority (“BRA”) on September 25, 2009. The IMPINF includes three new construction projects over the next 10 years: (1) Energy Facility – an approximately 48,000 square foot building on an existing parking lot located to the east of the Power Plant to improve energy efficiencies, ensure reliability, and support greener campus growth (“Proposed Project”); (2) Administration/Clinical Building – an approximately 160,000 square foot building on the surface parking lot located on the north side of the Power Plant along Albany Street; (3) New Inpatient Building – an approximately 405,000 square foot building on the Dowling Building site to support increased inpatient volume and the growth in Emergency Service and Trauma volume, which will necessitate the demolition of the Dowling Building. Notice of the receipt by the BRA of the IMPINF was published in the Boston Herald on September 25, 2009 initiating a public comment period ending on October 27, 2009.

In conjunction with the submission of the IMPINF, BMC submitted a Project Notification Form (“PNF”) which seeks Large Project Review, under Section 80B of the Code, for the Energy Facility Project (“Proposed Project”) as described above on September 25, 2009. Notice of the receipt by the BRA of the PNF was published in the Boston Herald on September 25, 2009 initiating a public comment period ending on October 27, 2009.

Pursuant to Section 80D-4.3c and Section 80B-5.3c of the Code a scoping session was held on October 13, 2009 with the City’s public agencies and to which members of the Task Force were invited and attended. Task Force

meetings, where the proposed IMP and Proposed Project were reviewed and discussed, were held on September 28, 2009 and October 13, 2009. The Task Force also toured the campus and met with key administrators on November 9, 2009. A public meeting was held on October 20, 2009. Based on the BRA's review of public comments and comments from the City's public agencies, the BRA hereby issues its Scoping Determination pursuant to Section 80D-4.3 and Section 80B-5.3 of the Code. Comments from the City's public agencies are attached and incorporated as a part of this Scoping Determination.

This Scoping Determination requests information required by the BRA for its review of the proposed IMP in connection with the following:

1. Approval of the Children's IMP pursuant to Article 80 and other applicable sections of the Code;
2. Recommendation to the Zoning Commission for approval of the BUMC Institutional Master Plan.

The BUMC IMP should be documented in a report of appropriate dimensions and in presentation materials which support the full review of the IMP. Twenty-five copies of the full IMP should be submitted to the BRA. An additional fifty copies should be available for distribution to the Task Force members, participants, community groups and other interested parties in support of the public review process. The IMP should be uploaded on the BUMC or other appropriate website so that it may be viewed electronically. The IMP should be submitted 1) as a stand-alone document, and 2) electronically in the form of CD's. The IMP should reference and/or include information from the Supplemental Materials that is also submitted to the BRA to meet the requirements of Large Project Review for the Proposed Project. The IMP document should include this Scoping Determination and text, maps, plans, and other graphic materials sufficient to clearly communicate the various elements of the IMP.

BUMC will be responsible for preparing and publishing in one or more newspapers of general circulation in the City of Boston a Public Notice of the submission of the IMP and Supplemental Materials to the BRA as required by Section 80A-2. This Notice shall be published within five (5) days after the receipt of the IMP and Supplemental Materials by the BRA. Public comments shall be transmitted to the BRA within sixty (60) days of the publication of this Notice, unless a time extension has been granted by the BRA in accordance with the provisions of Article 80 or to coordinate the IMP review with any required Large Project Review. Following publication of the Notice, BUMC shall submit to the BRA a copy of the published Notice together with the date of publication.

From: Gandhi, Sonal [Sonal.Gandhi.bra@cityofboston.gov]
Sent: Tuesday, October 13, 2009 4:07 PM
To: Kristi Dowd
Cc: Giers, Bob
Subject: FW: Boston Medical Center - IMP
 Kristi - Please see below.
 Bob – Thanks.
 Sonal

From: Giers, Bob
Sent: Tuesday, October 13, 2009 4:05 PM
To: Gandhi, Sonal
Cc: Jayasinghe, Para; Leo, Vincent; Banks, Joseph; Spinetto, Stephen; Crasco, Ken - Parks Dept.; McCarthy, Timothy (Public Works); Cardarelli, Mark; Goodfellow, Karin; 'Hopkins, Thomas (DPS)'
Subject: Boston Medical Center - IMP

hi Sonal, here are PWD comments for the subject project Phase I only, for the proposed new Energy Facility at 750 Albany Street, where the developer is estimating the cost of the project to be approximately \$ 82,000,000:

Site Plan:

Developer must provide an engineer's site plan at an appropriate engineering scale, that shows curb functionality on both sides of all streets that abuts the property. PWD 1

Sidewalks:

Developer is responsible for the reconstruction of the sidewalks abutting the project, and where appropriate, extend the limits to the nearest intersection. In order to improve pedestrian flow to and from the site and encourage and compliment pedestrian improvements and travel along all sidewalks within the Public Right of Way, the Developer is also requested to extend beyond the limits of the site other improvements to the immediate and relevant surrounding sidewalks and streets abutting the project. PWD 2

In order to enhance the accessibility to the pedestrian travel of the immediate area, the sidewalks and intersections within the project limits must meet the BPWD requirements and be brought into full compliance with the ADA/AAB. The reconstruction effort must meet current ADA guidelines, including the installation of new or reconstruction of existing compliant pedestrian ramps at all corners of all intersections. This effort may constitute a License, Maintenance and Indemnification (LM&I) agreement with the Public Improvement Commission (PIC).

NOTE: The developer is encouraged to contact Mr. Thomas Hopkins, Director of the Massachusetts Architectural Access Board, as needed, to ensure compliance with, and adherence to, the MAAB Rules and Regulations.

Discontinuances:

Any and all discontinuances (sub-surface, surface or above surface) within the Public Right-of-Way (ROW) must be processed through the PIC. PWD 3

Landscaping:

Developer must seek approval from Ken Crasco, Chief Landscape Architect with the Parks and Recreation Department for all landscape elements. Program must accompany a LM&I with the PIC. PWD 4

Street Lighting:

Street lighting needs must be consulted with Mr. Joe Banks of the Street Lighting Division with the PWD, and where needed, be installed by the developer, and must be consistent with the area lighting, to provide a consistent urban design. PWD 5

Roadway:

Based on the extent of construction activity, including utility connections and taps, the Developer will be responsible for the reconstruction of the roadway sections that immediately abuts the property, and where appropriate, extend the limits on re-construction to the nearest intersection. PWD 6

Roadway Clearance:

The Highway Division of Public Works is responsible for the clearance process pertaining to BPWD capital projects, such as reconstruction, resurfacing, etc. PWD 7

Developer must contact Mark Cardarelli in order to determine whether the development parcel(s) are on proposed capital projects or are free of conflict.

Public Trash Receptacles:

Developer to consult with Tim McCarthy of BPWD, and is responsible for purchasing solar powered trash compactors consistent with City of Boston's plan.

PWD 8

Public Art:

Developer is encouraged to contact Karin Goodfellow, Boston Arts Commission to participate with the City's public arts program, creating notable art pieces in public spaces.

PWD 9

Groundwater:

Developer should install groundwater-monitoring wells in accordance to ISD standards, to monitor groundwater levels during construction, and convey the wells to the Groundwater Trust through the PIC after the completion of the project.

PWD 10

Note: these are the general standard BPWD requirements applicable to every project, more detailed comments will be addressed during the PIC review process.

Any questions please give me a call at 617-635-4966

Thank you, Bob Giers

The substance of this message, including any attachments, may be confidential, legally privileged and/or exempt from disclosure pursuant to Massachusetts law. It is intended solely for the addressee. If you received this in error, please contact the sender and delete the material from any computer.

Help make the earth a greener place. If at all possible resist printing this email and join us in saving paper.

November 9, 2009

John Palmieri, Director
Boston Redevelopment Authority
Boston City Hall, Room 925
Boston, MA 02201
Attention: Sonal Gandhi, Senior Project Manager

Re: Boston Medical Center Energy Facility - Project Notification Form

Dear Director Palmieri:

The City of Boston Environment Department has reviewed the Project Notification Form (PNF) and offers the following comments.

The proponent, Boston Medical Center (BMC), part of Boston University Medical Center (BUMC), proposes to construct a new 48,000 square foot (sf), 100-foot tall combined heat and power (CHP) energy facility. Emission stacks will be 160 feet above ground level. The structure will have one below-grade level and four above. The project site is adjacent to the BMC "Power Plant," located at 750 Albany Street, north of the Massachusetts Avenue Connector and west of East Concord Street, and is bounded by a service area, existing buildings on two sides and a site for a future administration/clinical building for BMC. The project site is in the Groundwater Conservation Overlay District (GCOD) and the South End Protection District. Construction is expected to begin during the fourth quarter of 2010 and take about 18 months.

The Power Plant provides chilled water and is the steam and electric distribution center for the campus so is not a power plant in the true sense. Minor renovations will be made to the Power Plant to allow for circulation between the two buildings.

The goal of the project is to provide reliability, efficiency and reduced environmental impact using state-of-the-art technologies for the production of electricity and steam. It is expected that, through cogeneration, the plant will meet 95 percent of its high-pressure steam needs and 75 percent of the electrical needs for the BMC/BUMC campus. Cogeneration will result in energy costs lower than those associated with traditional systems.

BMC has already engaged in demand-side energy savings through the use of building automation systems, upgrades and replacement of systems, the centralization of mechanical systems and the installation of pipe and electrical infrastructure designed to accommodate the connection of separate utility systems at various locations on the campus.

The Energy Facility will use two combustion turbine generators (CTG) and two duct burners to provide supplemental steam to the existing distribution system. The turbines and duct burners will be equipped with NO_x, CO and VOC controls. They will be fueled by natural gas; fuel oil from an existing tank will be used to ensure operation in the event of an emergency. Heat recovery generators (HRC), auxiliary systems and ancillary equipment will also be part of the system. Auxiliary systems include condensate and feed water systems, control system, natural gas, chemical treatment, ammonia, fuel gas piping, gas compressors, plant air systems, HVAC systems and chilled water.

BMC expects that the facility will reduce its CO₂ emissions by 18,000 metric tons during the first year of operation. An Environmental Results Program Installation Compliance Certification for New Engines and Turbines (Non-Emergency) and a Non-Major Comprehensive Air Plans Approval application must be filed with the Massachusetts Department of Environmental Protection (DEP). The project will meet DEP requirements for Best Available Control Technology (BACT) and comply with National Ambient Air Quality Standards (NAAQS).

A service and loading dock will be located on the south side of the site. Combustion air inlet filters and a plenum will be located on Level Three. The Draft Project Impact Report (DPIR) should indicate if the dock will be fully enclosed and, if not, identify sound expected to result from its use and from building systems and the potential impacts on surrounding users such as laboratories, the office of the Chief Medical Examiner and the proposed clinical/administration building. The closest existing and proposed residential structures should be identified and any potential noise impacts described.

Air intakes and vents should be located as far as possible from pollutant sources (including the positioning of project vents away from project intakes) and from air intakes on adjacent buildings.

The PNF notes that there is no LEED rating system for a CHP facility. Despite that, important sustainability issues, many consistent with LEED credits, can be addressed through attention to the following:

- energy conservation through Energy Star windows;
- the conservation of non-process water;
- stormwater quantity and quality;
- solid waste recycling (An on-site area, appropriate for the small number of employees, should be established for solid waste recycling);
- light pollution reduction (Exterior lighting should meet safety needs while not contributing to light pollution. Fixtures should be shielded and downward directed. We recommend as a resource, the Campaign for Dark Skies which can be accessed at ['http://www.britastro.org/dark-skies/'](http://www.britastro.org/dark-skies/) – click 'Lighting' and then 'Good & bad lighting/.');
- parking capacity (absence of new parking);
- construction waste management;
- construction Indoor Air Quality Management Plan;
- the use of low-emitting materials, as appropriate for space usage;
- controllability of lighting and thermal comfort in areas such as the command and control center, conference room and facilities administration; and
- construction-period best practices.

BED 1

We request specifically that the proponent seriously consider a green roof. Flat roofs are particularly well suited for them; they can easily co-exist with mechanical systems. Benefits include stormwater retention, allowing for re-use or infiltration, the minimization of the heat island effect and a longer life-span than that expected for a non-planted roof.

BED 2

If there will be passenger-only elevators, this department suggests that the Proponent evaluate two elevator systems for the project – the Otis Elevator Company’s Gen2 model and Kone’s EcoSpace model.

BED 3

The Gen2, manufactured for two to 30-story buildings, requires a smaller sheave size than most standard, passenger elevators so the machine is mounted within the hoistway. Flat polyurethane-coated steel belts are used in place of cable. Otis describes the belts as more durable, flexible and space-saving. This elevator does not require additional lubrication and is advertised as providing a 50 percent reduction in energy use over conventional systems with a 75 percent reduction if combined with a regenerative drive.

Kone manufactures the EcoSpace Low-Rise Elevator, designed for two -10 landings. Kone states that 95 percent of EcoSpace materials are recyclable, that the elevator uses no oil, consumes about 33 percent less energy than that used by hydraulic machines and 50 percent less energy than a conventional traction machine.

We request the Proponent install permanent castings stating, “Don’t Dump: Drains to Boston Harbor,” on the sidewalk next to any catch basin existing, created or modified as part of the project. Plaques should also be installed at drains at other areas on the site.

BED 4

It appears that the emission stacks are not included in shadow diagrams. We look forward to diagrams with stacks in the DPIR that include the identification of doorways, bus stops, open space and areas where pedestrians are likely to congregate (in front of historic resources or other tourist destinations, for example) and clear delineation of shadow on both rooftops and facades.

BED 5

The DPIR should detail construction plans to ensure compliance with noise regulations and address air quality issues such as dust and particulates.

BED 6

The DPIR should indicate where any on site bicycle racks/storage will be located and, if no storage will be provided at the site, the two closest areas for bicycle parking for project staff.

BED 7

If the staff locker room will not have a shower, the DPIR should indicate the two closest shower areas on campus available to project staff.

According to the Massachusetts Department of Environmental Protection (DEP), about 33 percent of mobile source particulate matter (PM) and ten percent of all nitrogen oxide (NO_x) pollution in the northeast is caused by construction vehicles. More than 90 percent of diesel engine particulate emissions are highly respirable and carry toxins deep into the lung, exacerbating human respiratory ailments. The U. S. Environmental Protection Agency (EPA) has proposed classification of diesel exhaust as “highly likely to be carcinogenic in humans.” It estimates that diesel engines currently on the road can run for 1,000,000 miles and remain in operation for as long as 20 to 30 years. This amounts to 160 to 240 tons of pollution over the life of each engine.

The use of flow-through filters and diesel particulate filters on pre-2007 diesel vehicles can reduce air quality degradation caused by emissions of carbon monoxide (CO), volatile organic compounds (VOC), NO_x and air toxins generated by heavy-duty equipment. Oxidation catalysts and catalyzed particulate filters reduce toxic emissions of formaldehyde, benzene, acrolein and 1-3 butadiene by as much as 70 percent, decrease localized adverse impacts and reduce dust and odor complaints from project abutters and regulatory agencies. We ask that all pre-2007 diesel construction vehicles working on the project be retrofitted using retrofit technologies approved by the United States Environmental Protection Agency (EPA) and that contractors be required to use ultra low-sulfur diesel (ULSD) fuel (15 ppm), in all off-road construction equipment. BED 9

The South End Landmark District Commission (SELDC) looks forward to reviewing the proposed project. We note that the proposed stacks would be height is ten feet above the 150-foot limit in the Protection District. If the proposed height is required by regulation, please provide such information with the submission. BED 10

This department supports the proposed project and applauds BMC for choosing CHP and for its establishment and work of the Green Committee.

Thank you for the opportunity to offer comment. We look forward to the DPIR.

Sincerely,

Bryan Glascock
Director

Boston

Groundwater Trust

234 Clarendon St., Third Floor, Boston, MA 02116
617.859.8439 voice • 617.266.8750 fax
bostongroundwater.org

October 16, 2009

Board of Trustees

Gary L. Saunders
Tim Ian Mitchell
Co-chairs

Galen Gilbert
Nancy Grilk
Mary Hall
James W. Hunt III
Nikko Mendoza
Aaron Michlewitz
William Moy
Michael Nairne
Honorable Michael P. Ross
Molly Sherden
Peter Sherin

Executive Director

Elliott Laffer

Ms. Sonal Gandhi, Senior Project Manager
Boston Redevelopment Authority
One City Hall Square
Boston, MA 02201-1007

Subject: Boston Medical Center

Dear Ms. Gandhi:

Thank you for the opportunity to comment on the Institutional Master Plan Notification Form for the Boston Medical Center, as well as the Project Notification Form for the BMC Energy Facility. The Boston Groundwater Trust was established by the Boston City Council to monitor groundwater levels in sections of the city where the integrity of building foundations is threatened by low groundwater levels and to make recommendations for solving the problem. Therefore, my comments are limited to groundwater related issues.

I appreciate the acknowledgement by the proponent in both the IMPNF and the PNF that all of the planned projects are located in the Groundwater Conservation Overlay District and the commitment to meet the standards required in the GCOD. For the Energy Facility, which is the project that is more completely designed, I particularly appreciate the commitment in the PNF that the basement including walls and lowest level floor slab will be fully waterproofed, as well as the promise that no long term groundwater pumping will be allowed. The proponent committed in the scoping session to working with the Trust to determine the best location for the recharge system; I look forward to that effort. I also look forward to working with the proponent to determine the best location for the groundwater monitoring well that they have committed to install prior to the start of construction and appreciate that it will be installed in accordance with City and BGwT standards for permanent monitoring wells.

BGwT 1

BGwT 2

Because the project is to be constructed under an Institutional Master Plan and will not need the approval of the Board of Appeals, the process for assuring that groundwater standards are met and commitments are formalized should be spelled out in more detail. I look forward to participating in that effort.

BGwT 3

The commitments spelled out in these documents make me optimistic that the project will be designed and constructed in a way that can only lead to improvements in groundwater levels. I look forward to working with the proponent and the Authority to assure that this promise is kept.

Very truly yours,



Elliott Laffer
Executive Director

Cc: Kathleen Pedersen, BRA
Maura Zlody, BED

**Boston Water and
Sewer Commission**



980 Harrison Avenue
Boston, MA 02119-2540
617-989-7000

October 26, 2009

Ms. Sonal Gandhi
Economic Development
Boston Redevelopment Authority
One City Hall Square
Boston, MA 02201

Re: Project Notification Form- Boston University Medical Center Energy Facility

Dear Ms. Gandhi:

The Boston Water and Sewer Commission (BWSC) has reviewed the Project Notification Form (PNF) for the proposed Boston Medical Center Energy Facility (Energy Facility).

The proposed Energy Facility will be located adjacent to the existing Boston Medical Power Plant at 750 Albany Street. The site is currently paved and is entirely impervious. The adjacency to the existing Power Plant is necessary in order to tie into the existing system and enhance operational efficiency. The proposed Energy Facility is comprised of spaces designated for primary mechanical equipment such as combustion turbine generators and heat recovery steam generators, auxiliary systems and ancillary equipment, and the associated distribution infrastructure. Other programmed spaces include a control room, a break room, and a locker room.

The project site is served by a 12-inch high and a 12-inch low pressure line located on Albany Street. Water demand for the Energy Facility is estimated at 435,000 gpd, with a peak demand of 640 gpd for water service. It is anticipated that to maintain uninterrupted water services, separate potable water supply, and fire protection services, supply will be provided from the 12-inch mains on Albany Street. Water supply for steam generation will be provided from the 12-inch low main. Fire protection service will be from the 12-inch high main.

It is estimated that the Energy Facility will generate an estimated 31,800 gallons per day (gpd) of wastewater with a peak discharge of 85 gpm. Most of the wastewater generated will be from process water during the steam generation and condensate. It is anticipated that for sewer service the project will tie directly into the existing sewer services from the Power Plant and Medical Examiner's office which are connected to the 60-inch service at the rear of the site. No new direct connection to the sewer interceptors in the area is proposed and the construction of new sewer mains is not anticipated.

The proponent anticipates that any runoff from non-roof areas and storms in excess of 1-inch of rainfall will be conveyed through existing infrastructure to the Roxbury Canal Conduit.

The proposed structure includes one level below grade and will subsequently involve some subsurface excavation. The foundation elements that are required to extend down to competent soils, below groundwater level, will be solid, discontinuous, discrete elements that will not cause the groundwater to raise, pond or be lowered.

The Energy Facility is located within the Groundwater Conservation Overlay District (GCOD). As such, the project will be required to infiltrate 1-inch of runoff per square foot of new building footprint. The proponent anticipates accomplishing this with a subsurface infiltration system. The system may be designed to accept clean roof runoff and infiltrate it to the ground. As the existing project area is entirely impervious and a new subsurface infiltration system will be installed, any infiltration of stormwater from the proposed project is expected to have a positive effect on groundwater levels in the area. Methods to assure that the project will not result in any negative impacts to the groundwater levels will include fully waterproofed basement (walls and lowest level floor slabs) for the portion of the structure that extends below groundwater levels. Design criteria for the project will include a provision that no long term groundwater pumping will be allowed.

The Commission met with the project proponent's representatives on October 13, 2009, and preliminary plans for the Energy Facility were discussed.

The Commission submits the following comments regarding the proposed Energy Facility:

General

1. The proponent must submit a site plan and a General Service Application to the Commission for the project. The site plan must show the location of existing public and private water mains, sanitary sewers and storm drains serving the project site, as well as the locations of proposed service connections. BWSC 1
2. It is the proponent's responsibility to evaluate the capacity of the water, sewer and storm drainage systems serving the project site to determine if the systems are adequate to meet future project demands. With the site plan the proponent must provide an analysis of the impacts of the proposed project on the Commission's water, sewer and storm drainage systems. BWSC 2

3. With the site plan, the proponent must provide detailed and updated estimates for water demand, wastewater generation, and stormwater runoff for the proposed project. Estimates of water demand and wastewater generation relating to domestic uses must be quantified and provided separately from estimates for the co-generation process. BWSC 3

4. The proponent is advised that should it be determined later that new, relocated, reconstructed or expanded water, sanitary sewer, or storm drainage pipes are required to accommodate the project, the facilities must be designed and constructed at the proponent's expense and in conformance with the Commission's Sewer Use and Water Distribution System regulations. The proponent should continue to keep the Commission apprised of any proposed plans regarding the sanitary sewer, storm drainage or drinking water systems. BWSC 4

5. To assure compliance with the Commission's requirements, the proponent should submit the site plan and General Service Application to the Commission for review when project design is 50 percent complete. BWSC 5

Sewage/Drainage

6. Separate sanitary sewer and storm drain services must be provided from the new facility to the respective pipe in the street. BWSC 6

7. The site plan must show in detail how drainage from building roofs and from other impervious areas will be managed. Roof runoff and other stormwater runoff must be conveyed separately from sanitary waste at all times. BWSC 7

8. The Department of Environmental Protection (DEP), in cooperation with the Massachusetts Water Resources Authority (MWRA) and its member communities, are implementing a coordinated approach to flow control in the MWRA regional wastewater system, particularly the removal of extraneous clean water (e.g., infiltration/ inflow (I/I)) in the system. In this regard, DEP has been routinely requiring proponents proposing to add significant new wastewater flow to assist in the I/I reduction effort to ensure that the additional wastewater flows are offset by the removal of I/I. Currently, DEP is typically using a minimum 4:1 ratio for I/I removal to new wastewater flow added. The Commission supports the DEP/MWRA policy, and will require the proponent to develop a consistent inflow reduction plan. BWSC 8

9. The proponent must fully investigate methods for retaining stormwater on the project site before the Commission will consider requests to discharge additional stormwater to the Commission's system. Under no circumstances will stormwater be allowed to discharge to a BWSC 9

sanitary sewer. A feasibility assessment for retaining stormwater on site must be submitted with the site plan.

10. The discharge of dewatering drainage to a sanitary sewer is prohibited by the Commission. The proponent is advised that the discharge of any construction site dewatering drainage to the storm drainage system requires a Drainage Discharge Permit from the Commission. If the dewatering drainage is contaminated with petroleum products for example, the proponent will be required to obtain a Remediation General Permit from Environmental Protection Agency (EPA) for the discharge.

BWSC 10

11. In conjunction with the site plan and General Service Application the proponent will be required to submit a Stormwater Pollution Prevention Plan. The plan must:

BWSC 11

- Identify specific best management measures for controlling erosion and preventing the discharge of sediment, contaminated stormwater or construction debris to the Commission's drainage system when construction is underway.
- Include a site map which shows, at a minimum, existing drainage patterns and areas used for storage or treatment of contaminated soils, groundwater or stormwater, and the location of major control or treatment structures to be utilized during construction.
- Specifically identify how the project will comply with the Department of Environmental Protection's Performance Standards for Stormwater Management both during construction and after construction is complete.

Water


12. The Commission utilizes a Fixed Radio Meter Reading System to obtain water meter readings. Where a new water meter is needed, the Commission will provide a Meter Transmitter Unit (MTU) and connect the device to the meter. For information regarding the installation of MTUs, the proponent should contact the Commission's Meter Installation Department.

BWSC 12

13. The proponent should explore opportunities for implementing water conservation measures in addition to those required by the State Plumbing Code. In particular the proponent should consider outdoor landscaping which requires minimal use of water to maintain. If the proponent plans to install in-ground sprinkler systems, the Commission recommends that timers, soil moisture indicators and rainfall sensors be installed. The use of sensor-operated faucets and toilets in common areas of buildings should also be considered.

BWSC 13

Thank you for the opportunity to comment on this project.

Yours truly,

John P. Sullivan, P.E.
Chief Engineer

JPS/as

cc:

M. Zlody, Boston Env. Dept.
P. Laroque, BWSC
R. Bartlett, Vice President for Finance, BMCC
J. Hobbs, President, RFWalsh collaborative partners



51 Sleeper Street • Boston, Massachusetts • 02210-1208 • 617-778-0900

WWW.RFWCOLLABORATIVEPARTNERS.COM